



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 13, 2008

RE: SUMMIT COUNTY
NORTON ACRES WWTP #13
PRE-PERMIT INSPECTION
APPLICATION NO. OH0045853
OHIO EPA NO. 3PH00008

Mr. David E. Marquard
Summit County, Environmental Services
2525 State Road
Cuyahoga Falls, OH 44223

Dear Mr. Marquard:

On May 9, 2008, an NPDES pre-permit inspection was conducted by this writer of Northeast District Office. Present during the inspection were Bob Frank and Jeff Muckleroy of Summit County, Environmental Services.


The 121,000 gpd wastewater treatment plant consists of a comminutor, extended aeration, secondary clarifier, ultraviolet disinfection, post aeration, and an aerobic digester. All components of the treatment plant appeared to be operating properly, and the effluent appeared clear.

Review of the Discharge Monitoring Reports from April 2006 through April 2008 revealed the following numeric effluent violations:

Parameter	Limit Type	Limit	Reported Value	Violation Date
Total Suspended Solids	7D Qty	13.6	15.7357	1/15/2007
Total Suspended Solids	30D Conc	20	21.1428	12/1/2006
Total Suspended Solids	30D Qty	9.1	9.28671	3/1/2008
Total Suspended Solids	7D Qty	13.6	18.1112	3/1/2008

The Public Notice of the draft NPDES permit will be published. Please read the draft permit carefully. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,


Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/mt