



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Henry County
Liberty Center WWTP
Ohio EPA Permit No. 2PB00039
NPDES Permit No. OH0029289

JuLY 1, 2010

Mr. Frank Godwin, Utilities Superintendent
Village of Liberty Center
P. O. Box 91
Liberty Center, Ohio 43532

Dear Mr. Godwin:

We are in receipt of your discharge-monitoring reports covering the months of February 2008,–May 2010, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached.

When entering explanation codes, such as AH, you must enter a note in eDMR justifying the use of the code. Failure to document appropriate codes with descriptive comments may result in a notice of violation.

For permit violations occurring from February 2008,–May 2010, you have informed this office as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Please follow up with Ohio EPA Central Office to make sure you have corrected any data that was captured incorrectly in the eDMR data base.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. f these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction).

Mr. Frank Godwin, Utilities Superintendent
July 1, 2010
Page 2

For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner.

You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or US EPA's facility Pollution Prevention Guide (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact this office.

Sincerely,


Dana Martin-Hayden
Division of Surface Water

/llr

pc: DSW-NWDO-File - - -]

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00039*ID	August 2009	001	31616	Fecal Coliform	7D Conc	2000	5000.	8/22/2009
2PB00039*ID	April 2010	001	00530	Total Suspended Solids	30D Conc	30	47.8444	4/1/2010
2PB00039*ID	April 2010	001	00530	Total Suspended Solids	7D Conc	45	114.533	4/22/2010
2PB00039*ID	April 2010	001	00530	Total Suspended Solids	30D Qty	28	32.4077	4/1/2010
2PB00039*ID	April 2010	001	00530	Total Suspended Solids	7D Qty	43	83.8433	4/22/2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit Value	Reported Value	Violation Date
2PB00039*ID	June 2008	801	31616	Fecal Coliform			AF	6/17/2008
2PB00039*ID	June 2008	901	31616	Fecal Coliform			AF	6/17/2008
2PB00039*ID	October 2008	001	50050	Flow Rate			AD	10/3/2008
2PB00039*ID	October 2008	001	50050	Flow Rate			AD	10/4/2008
2PB00039*ID	October 2008	001	50050	Flow Rate			AD	10/5/2008
2PB00039*ID	October 2008	001	50050	Flow Rate			AD	10/6/2008
2PB00039*ID	October 2008	001	50050	Flow Rate			AD	10/7/2008
2PB00039*ID	October 2008	001	50050	Flow Rate			AD	10/8/2008
2PB00039*ID	January 2009	801	00010	Water Temperature			AF	1/1/2009
2PB00039*ID	January 2009	801	00400	pH			AF	1/1/2009
2PB00039*ID	January 2009	801	00300	Dissolved Oxygen			AF	1/1/2009
2PB00039*ID	January 2009	901	00010	Water Temperature			AF	1/1/2009
2PB00039*ID	January 2009	901	00400	pH			AF	1/1/2009
2PB00039*ID	January 2009	901	00300	Dissolved Oxygen			AF	1/1/2009
2PB00039*ID	January 2010	801	00010	Water Temperature			AF	1/1/2010
2PB00039*ID	January 2010	801	00400	pH			AF	1/1/2010
2PB00039*ID	January 2010	801	00300	Dissolved Oxygen			AF	1/1/2010
2PB00039*ID	January 2010	901	00010	Water Temperature			AF	1/1/2010
2PB00039*ID	January 2010	901	00400	pH			AF	1/1/2010
2PB00039*ID	January 2010	901	00300	Dissolved Oxygen			AF	1/1/2010
2PB00039*ID	February 2010	801	00010	Water Temperature			AF	2/1/2010
2PB00039*ID	February 2010	801	00400	pH			AF	2/1/2010
2PB00039*ID	February 2010	801	00300	Dissolved Oxygen			AF	2/1/2010
2PB00039*ID	February 2010	901	00010	Water Temperature			AF	2/1/2010
2PB00039*ID	February 2010	901	00400	pH			AF	2/1/2010
2PB00039*ID	February 2010	901	00300	Dissolved Oxygen			AF	2/1/2010
2PB00039*ID	December 2009	001	00530	Total Suspended Solids			AB	12/17/2009
2PB00039*ID	December 2009	001	80082	CBOD 5 day			AB	12/17/2009
2PB00039*ID	December 2009	601	00530	Total Suspended Solids			AB	12/17/2009
2PB00039*ID	December 2009	601	80082	CBOD 5 day			AB	12/17/2009

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
2PB00039*ID	October 2008	001	00530	Total Suspended Solids	2/Week	2	1	10/22/2008
2PB00039*ID	October 2008	001	80082	CBOD 5 day	2/Week	2	1	10/22/2008