

Riverbend Bldg



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Notice of Violation  
Henry County  
Ohio EPA Permit No. 2PY00026  
NPDES Permit No. OH0125521

June 21, 2007

Mr. Robert W. Maurer, Esq.  
River Bend Mobile Home Park  
224 E. Wooster Street  
Bowling Green, Ohio 43402

Dear Mr. Maurer:

We are in receipt of your self monitoring reports covering the months of June 2006 to June 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/3/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/6/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/9/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/13/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/16/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/18/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/22/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/25/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	0	3/29/2007
March 2007	001	pH	1D Conc	6.5	1.	3/3/2007
March 2007	001	pH	1D Conc	6.5	0	3/6/2007
March 2007	001	pH	1D Conc	6.5	0	3/9/2007
March 2007	001	pH	1D Conc	6.5	0	3/13/2007
March 2007	001	pH	1D Conc	6.5	0	3/16/2007
March 2007	001	pH	1D Conc	6.5	1.	3/18/2007
March 2007	001	pH	1D Conc	6.5	1.	3/22/2007
March 2007	001	pH	1D Conc	6.5	1.	3/25/2007
March 2007	001	pH	1D Conc	6.5	1.	3/29/2007
March 2007	001	Nitrogen, Ammonia	1D Conc	4.5	8.	3/3/2007
March 2007	001	Nitrogen, Ammonia	1D Qty	0.085	0.09084	3/3/2007
March 2007	001	Nitrogen, Ammonia	1D Conc	4.5	6.9	3/18/2007
March 2007	001	Nitrogen, Ammonia	30D Conc	3.0	7.45	3/1/2007
March 2007	001	Nitrogen, Ammonia	30D Qty	0.057	0.08459	3/1/2007

Mr. Robert Maurer  
June 21, 2007  
Page Two

Frequency Violations						
Reporting Period	Violation Date	Reporting Code	Parameter	Sample Frequency	Expected	Reported
March 2007	3/1/2007	01330	Odor, Severity	1/Week	1	0
March 2007	3/8/2007	01330	Odor, Severity	1/Week	1	0
March 2007	3/22/2007	01330	Odor, Severity	1/Week	1	0
March 2007	3/1/2007	01350	Turbidity, Severity	1/Week	1	0
March 2007	3/8/2007	01350	Turbidity, Severity	1/Week	1	0
March 2007	3/22/2007	01350	Turbidity, Severity	1/Week	1	0

Please inform this office in writing within **10 days** of receipt of this letter as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://www.epa.state.oh.us/ocapp/ocapp.html> or by calling (614)644-3469.

If there are any questions, please contact me at 419-373-3053 or at [tanushree.sinha@epa.state.oh.us](mailto:tanushree.sinha@epa.state.oh.us).

Sincerely,



Tanushree (Nush) S. Courlas  
Environmental Specialist II  
Division of Surface Water

/lb

pcg DSW-NWBG-File