Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Notice of Violation
Huron County
Fieldcrest MHP
Sewerage
Ohio EPA Permit No. 2PY00031

October 29, 2010

Mr. Richard Mayell, Owner
Fieldcrest MHP
12718 Drake Road
North Royalton, Ohio 44133

Dear Mr. Mayell:

We are in receipt of your self-monitoring report covering the months of March 2010 ,through August 2010, for the referenced facility. Our review indicates violations of the conditions of your NPDES permits. Further review indicates that you are in significant non-compliance (SNC) with several effluent limitations contained in that NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Within **14 days** of receiving this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the *generation of wastes and pollutants at the source (source reduction). For those wastes* or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's *"Facility Pollution Prevention Guide"* (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

If there are any questions, please contact me at (419) 373-3003.

Sincerely,

Andrew Y. Gall
Division of Surface Water

/llr

Enclosure

pc: Mr. Robert Lyn Makeever, Operator w/enclosures
Huron County Health Department
DSW-NWDO File w/enclosure

Get New Data | Get Detail for Selected Permit

Facilities in Significant Non-Compliance **

Period: Mar-10 Aug-10

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Huron	2PY00031	Fieldcrest MHP		1	00610	Nitrogen, Ammonia (NH3)	1930	3	3

Footnotes

for Significant NonCompliance

** Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
   a. 40% for Group 1 pollutants **plus Fecal Coliform**
   b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**

- - or - -

2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:
- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00031*CD	April 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	3.0	8.67	4/1/2010
2PY00031*CD	April 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	4.5	8.67	4/20/2010
2PY00031*CD	May 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	20.3	5/1/2010
2PY00031*CD	May 2010	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.04	.17672	5/1/2010
2PY00031*CD	May 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	20.3	5/10/2010
2PY00031*CD	May 2010	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.06	.17672	5/10/2010
2PY00031*CD	May 2010	001	00400	pH	1D Conc	6.5	6.4	5/10/2010
2PY00031*CD	June 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	2.82	6/1/2010
2PY00031*CD	June 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	2.82	6/22/2010
2PY00031*CD	July 2010	001	00530	Total Suspended Solids	30D Conc	12	29.	7/1/2010
2PY00031*CD	July 2010	001	00530	Total Suspended Solids	1D Conc	18	29.	7/19/2010
2PY00031*CD	July 2010	001	00400	pH	1D Conc	6.5	6.3	7/19/2010