



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: **Notice of Violation**
Huron County
Willard MHP
Ohio EPA Permit No. 2PY00052

October 29 2010

Mr. Dan Inks
IRBW Properties Ltd.
dba Willard Mobile Home Park
9 Corporation Center
Broadview Heights, Ohio 44147

Dear Mr. Inks:

We are in receipt of your self-monitoring report covering the months of April 2010, through August 2010, for the referenced facility. Our review indicates violations of the conditions of your NPDES permits. Further review indicates that you are in significant non-compliance (SNC) with several effluent limitations contained in that NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Within **14 days** of receiving this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Mr. Dan Inks
October 29, 2010
Page 2

If there are any questions, please contact me at (419) 373-3003.

Sincerely,

A handwritten signature in cursive script that reads "Andrew Y. Gall". The signature is written in dark ink and is positioned above the printed name.

Andrew Y. Gall
Division of Surface Water

//lr

Enclosure

pc: Mr. Robert Lyn Makeever, Operator w/enclosures
Huron County Health Department
DSW-NWDO File w/enclosure }

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00052*BD	April 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	3.6	4/1/2010
2PY00052*BD	May 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	3.7	5/1/2010
2PY00052*BD	May 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.113	.86828	5/1/2010
2PY00052*BD	May 2010	001	80082	CBOD 5 day	30D Qty	0.57	1.17335	5/1/2010
2PY00052*BD	May 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	3.7	5/12/2010
2PY00052*BD	May 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.17	.86828	5/12/2010
2PY00052*BD	May 2010	001	80082	CBOD 5 day	1D Qty	0.85	1.17335	5/12/2010
2PY00052*BD	May 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	2.73	5/12/2010
2PY00052*BD	May 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	4.48	5/26/2010
2PY00052*BD	June 2010	001	00530	Total Suspended Solids	30D Qty	0.68	.7078	6/1/2010
2PY00052*BD	June 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	12.1	6/1/2010
2PY00052*BD	June 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.113	.77857	6/1/2010
2PY00052*BD	June 2010	001	80082	CBOD 5 day	30D Conc	10	24.	6/1/2010
2PY00052*BD	June 2010	001	80082	CBOD 5 day	30D Qty	0.57	1.54428	6/1/2010
2PY00052*BD	June 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	3.54	6/2/2010
2PY00052*BD	June 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	12.1	6/9/2010
2PY00052*BD	June 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.17	.77857	6/9/2010
2PY00052*BD	June 2010	001	80082	CBOD 5 day	1D Conc	15	24.	6/9/2010
2PY00052*BD	June 2010	001	80082	CBOD 5 day	1D Qty	0.85	1.54428	6/9/2010
2PY00052*BD	June 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	1.77	6/9/2010
2PY00052*BD	June 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	.97	6/16/2010
2PY00052*BD	June 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	1.46	6/23/2010
2PY00052*BD	June 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	2.5	6/30/2010
2PY00052*BD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	8/4/2010
2PY00052*BD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	8/11/2010
2PY00052*BD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	8/18/2010
2PY00052*BD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	8/25/2010