



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: **Notice of Violation**  
Huron County  
Woodlyn Acres MHP  
Ohio EPA Permit No. 2PY00025

March 3, 2010

Mr. Dennis Lugli, Owner  
Woodlyn Acres MHP  
1304 County Road 16  
New London, Ohio 44851

Dear Mr. Lugli:

We are in receipt of your self-monitoring report covering the months of August 2009 through January 2010 for the wastewater treatment plant serving your facility. Our review indicates violations of the conditions of your NPDES permits. Further review indicates that you are in significant non-compliance (SNC) with several effluent limitations contained in that NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

The following web address contains useful eDMR submission information including definitions of limit violations, nonnumeric violations, frequency violations, calculation of average concentrations, and correct A-code use; <http://www.epa.ohio.gov/dsw/edmr/eDMR.aspx>.

Within **14 days** of receiving this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Mr. Dennis Lugli  
March 3, 2010  
Page Two

If there are any questions, please contact me at (419) 373-3003.

Sincerely,



Andrew Y. Gall  
Division of Surface Water

/cs

Enclosure

pc: Mr. Darryl Young  
Huron County Health Department  
NWDO-DSW File w/enclosure

## Detail - Limit Violations

Permit: 2PY00025

Period: 8/1/2009 1/31/2010

Permit No	Facility	Report Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00025*CD	Woodlyn Acres Moter Home Park	Aug 2009	001	00530	Total Suspended Sol	30D Conc	12	51.	8/1/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Aug 2009	001	00530	Total Suspended Sol	30D Qty	1.37	1.81453	8/1/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Aug 2009	001	00530	Total Suspended Sol	1D Conc	18	51.	8/31/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Aug 2009	001	31616	Fecal Coliform	1D Conc	2000	2500.	8/31/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Sep 2009	001	00530	Total Suspended Sol	30D Conc	12	18.	9/1/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Sep 2009	001	50060	Chlorine, Total Resid	1D Conc	0.019	.79	9/10/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Oct 2009	001	00530	Total Suspended Sol	30D Conc	12	22.	10/1/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Oct 2009	001	00400	pH	1D Conc	6.5	6.32	10/14/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Oct 2009	001	00530	Total Suspended Sol	1D Conc	18	22.	10/14/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Oct 2009	001	50060	Chlorine, Total Resid	1D Conc	0.019	.43	10/14/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Oct 2009	001	50060	Chlorine, Total Resid	1D Conc	0.019	.67	10/27/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Dec 2009	001	00400	pH	1D Conc	6.5	6.25	12/2/2009
2PY00025*CD	Woodlyn Acres Moter Home Park	Jan 2010	001	00610	Nitrogen, Ammonia (	30D Qty	0.34	.43967	1/1/2010
2PY00025*CD	Woodlyn Acres Moter Home Park	Jan 2010	001	00610	Nitrogen, Ammonia (	30D Conc	3.0	9.68	1/1/2010
2PY00025*CD	Woodlyn Acres Moter Home Park	Jan 2010	001	00610	Nitrogen, Ammonia (	1D Conc	4.5	9.68	1/13/2010