



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Lucas County
Arrowhead Lake MHP
NPDES permit

April 21, 2010

Ms. Annabell E. Auler, MHM, PHC
Mc Equites Regional Manager
990 Beach Avenue Suite 114
Vancouver, BC V6Z 2N9

Dear Ms. Auler:

On April 14, 2010, I conducted an inspection of the Sewage treatment plant serving Arrowhead Lake MHP, Swanton Township, Lucas County. Mr. Allen Slusher provided information regarding the operation of the plant.


During the inspection, I noticed that some components of the approved plant improvements have not been completed, which include replacement of the sand filter media in two filters, the addition of a de-chlorination unit, and the installation of a flow meter.

Our records indicate continued discharge limitation violations. Please note that the approved improvements must be completed so the violations can be corrected and prevented in the future.

Please inform this office by May 15, 2010, of the expected date of the completion of the approved improvements.

If you have any question regarding the above, please contact me at naajy.abdullah@epa.state.oh.us or (419) 373-3017.

Sincerely,


Naajy Abdullah, P.E.
Division of surface Water

/llr

pc: DSW-NWDO File