



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Lucas County
Whispering Wind MHC
NPDES Permit

May 17, 2010

Ms. Cindy Stein
Grand View LLC
3203 West Lincolnshire Blvd
Toledo, Ohio 43606

Dear Ms. Stein:

On April 20, 2010, I conducted an inspection of the sewage treatment facility serving Whispering Winds MHC, Neapolis, Lucas County.

The plant was operating at the time of inspection. A slight septic odor was present within the plant's building. The influent suction lift pumps appear to have been replaced by submersible pumps which I was not able to look at due to accessibility issues. The monthly operating reports indicate that the current plant discharge exceeds the permit limits for several pollutants.

Our office is currently reviewing detail plans for modifications to the current treatment plant. The plans needed revisions and will be processed as soon as they are complete.

If you have any questions, please contact me at naajy.abdullah@epa.state.oh.us or (419) 373-3017.

Sincerely,

Naajy Abdullah, P.E.
Division of Surface Water

/lb

pc: **NWDO DSW-File**
Toledo-Lucas County Health Department