



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE (419) 352-8461 FAX (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Lucas County
City of Toledo
Water Treatment Plant
NPDES Permit

September 3, 2008

Mr. John Walthall, Manager
Water Treatment Plant
P.O. Box 786
Toledo, Ohio 43697


Dear Mr. Walthall:

On August 27, 2008, I conducted an inspection of the wastewater discharge outfalls at the Water Treatment Plant. Mr. Chris Taylor and Mr. James Dillon provided information on the outfalls.

The plant has nine discharge outfalls from five lime sludge lagoons that are used to treat lime sludge and filter backwash generated from the water treatment processes. Only outfalls 006 and 010 were discharging at the time of the inspection. It was indicated that outfall 010 was added to replace outfall 001 which serves lagoon A and outfall 001 will be retained for future use.

We are in receipt of the renewal application for the NPDES permit and will soon process it. If you have any questions, please contact me at (419) 373-3017.

Sincerely,


Naajy S. Abdullah, P.E.
Division of Surface Water

/llr

pc: DSW-NWDO File