



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE (419) 352-8461 FAX (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Marion County
Prospect WWTP
NPDES Permit

January 17, 2008

Mayor and Council
Village of Prospect
139 N. Main Street
Prospect, Ohio 43342

Dear Mayor and Council:

On October 11, 2007, Jason Ko conducted a compliance inspection at your wastewater treatment plant (WWTP), located on south State Route 203. Mr. Ken Blue was present and provided information regarding the operation of the facility.

The plant expansion/improvement project was completed in May 2007. At the time of the inspection, all major treatment components were in service. The mixed liquor in the oxidation ditch was a dark brown color. The final discharge from the plant appeared to be visually clear. However, we did not collect any effluent samples to determine the water quality of the discharge during the visit.

Please note that your National Pollutant Discharge Elimination System permit (2PA00041*HD) became effective on December 1, 2005, and will expire on July 31, 2010. Our review of your self-monitoring reports (1/2006 to 9/2007) for this facility showed numerous effluent violations. Please refer to the enclosed violation table. The recent plant expansion will hopefully eliminate many of the effluent violations.

A copy of our completed inspection report is included for your review. If you have any questions, please call Mr. Jason Ko of our office at 419-373-3021.

Yours truly,

Allen L. Rupp, P.E.
District Engineer/Section Manager
Division of Surface Water

JKllr

pc: Ken Blue, Village Administrator
DSW-NWDO File

NPDES COMPLIANCE INSPECTION REPORT

Section A: National Data System Coding

Permit #	NPDES	Yr/Mo/Day	Inspection Type	Inspector	FacType
<u>2PA00041</u>	<u>OH0047902</u>	<u>2007-10-11</u>	<u>C</u>	<u>S</u>	<u>1</u>

Section B: Facility Data

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Prospect WWTP	10:30 a.m.	12-1-2005
State Route 203 South	Exit Time	Permit Expiration Date
Prospect, Ohio 43342	11:30 a.m.	7-31-2010
Name(s) and Title(s) of On-Site Representative(s)		Phone Number(s)
Ken Blue, Village Administrator		740-494-2223
Name, Address and Title of Responsible Official		Phone Number
Mayor & Council		740-494-2115
Village of Prospect		
139 N. Main Street		
Prospect, Ohio 43342		

Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>--</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>--</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>--</u> Other

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

- * Plant improvements to double the design treatment capacity of the existing WWTP were completed May 2007
- * Plant effluent was clear
- * Cursory review of your monthly monitoring reports (Jan 2006 - Sept 2007) indicated numerous effluent violations




Jason Ko
Name(s) and Signature(s) of Inspector(s)

11/17/08

Date

Ohio EPA, Northwest
District Office



Elizabeth A. Wick, P.E.
Name and Signature of Reviewer

11/17/08

Date

Ohio EPA, Northwest
District Office

Sections E thru K: Complete on all inspections as appropriate. N/A - Not Applicable N/E - Not Evaluated

Section E: Permit Verification				
	Yes	No	N/A	N/E
INSPECTION OBSERVATIONS VERIFY THE PERMIT				
(a) CORRECT NAME AND MAILING ADDRESS OF PERMITTEE	<u>X</u>	___	___	___
(b) CORRECT NAME AND LOCATION OF RECEIVING WATERS	<u>X</u>	___	___	___
(c) PRODUCT(S) AND PRODUCTION RATES CONFORM WITH PERMIT APPLICATION (INDUSTRIES)	___	___	<u>X</u>	___
(d) FLOWS AND LOADINGS CONFORM WITH NPDES PERMIT PERMIT APPLICATION/BRIEFING MEMO	<u>X</u>	___	___	___
(e) TREATMENT PROCESSES ARE AS DESCRIBED IN PERMIT APPLICATION/BRIEFING MEMO	<u>X</u>	___	___	___
(f) NEW TREATMENT PROCESS(ES) ADDED SINCE LAST INSPECTION	___	<u>X</u>	___	___
(g) NOTIFICATION GIVEN TO STATE OF NEW, DIFFERENT OR INCREASED DISCHARGES	___	___	<u>X</u>	___
(h) ALL DISCHARGES ARE PERMITTED	<u>X</u>	___	___	___
(i) NUMBER AND LOCATION OF DISCHARGE POINTS ARE AS DESCRIBED IN PERMIT	<u>X</u>	___	___	___
COMMENTS/STATUS:				

* WWTP was doubled and plant upgrades were completed in 5/2007

Section F: Compliance Schedules/Violations				
	Yes	No	N/A	N/E
(a) ANY SIGNIFICANT VIOLATIONS SINCE THE LAST INSPECTION	___	<u>X</u>	___	___
(b) PERMITTEE IS TAKING ACTIONS TO RESOLVE VIOLATIONS	___	___	<u>X</u>	___
(c) PERMITTEE HAS COMPLIANCE SCHEDULE	___	___	<u>X</u>	___
(d) COMPLIANCE SCHEDULE CONTAINED IN _____	___	___	<u>X</u>	___
(e) PERMITTEE IS MEETING COMPLIANCE SCHEDULE	___	___	<u>X</u>	___
COMMENTS/STATUS:				

Section G: Operation and Maintenance

TREATMENT WORKS:

	Yes	No	N/A	N/E
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED				
(a) STANDBY POWER AVAILABLE GENERATOR <u>X</u> DUAL FEED <u> </u>	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(b) ADEQUATE ALARM SYSTEM AVAILABLE FOR POWER OR EQUIPMENT FAILURES	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(c) ALL TREATMENT UNITS IN SERVICE OTHER THAN BACKUP UNITS	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(d) SUFFICIENT OPERATING STAFF PROVIDED # SHIFTS <u>1</u> DAYS/WEEK <u>5</u>	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(e) OPERATOR HOLDS UNEXPIRED LICENSE OF CLASS <u> </u> REQUIRED BY PERMIT CLASS: <u>III</u>	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(f) ROUTINE AND PREVENTIVE MAINTENANCE SCHEDULED/PERFORMED ON TIME	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(g) ANY MAJOR EQUIPMENT BREAKDOWN SINCE LAST INSPECTION	<u> </u>	<u>X</u>	<u> </u>	<u> </u>
(h) OPERATION AND MAINTENANCE MANUAL PROVIDED AND MAINTAINED	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(i) ANY PLANT BYPASSES SINCE LAST INSPECTION	<u> </u>	<u>X</u>	<u> </u>	<u> </u>
(j) REGULATORY AGENCY NOTIFIED OF BYPASSES <u> </u> ON MORS <u>X</u> 800 NO.	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(k) ANY HYDRAULIC AND/OR ORGANIC OVERLOADS EXPERIENCED SINCE LAST INSPECTION	<u> </u>	<u>X</u>	<u> </u>	<u> </u>

COLLECTION SYSTEM:

	Yes	No	N/A	N/E
(a) PERCENT COMBINED SYSTEM <u>0</u> %				
(b) ANY COLLECTION SYSTEM OVERFLOWS SINCE LAST INSPECTION (CSO <u> </u> SSO <u> </u>)	<u> </u>	<u> </u>	<u>X</u>	<u> </u>
(c) REGULATORY AGENCY NOTIFIED OF OVERFLOWS (SSOs)	<u> </u>	<u> </u>	<u>X</u>	<u> </u>
(d) CSO O AND M PLAN PROVIDED AND IMPLEMENTED	<u> </u>	<u> </u>	<u>X</u>	<u> </u>
(e) CSOs MONITORED AND REPORTED IN ACCORDANCE WITH PERMIT	<u> </u>	<u> </u>	<u>X</u>	<u> </u>
(f) PORTABLE PUMPS USED TO RELIEVE SYSTEM	<u> </u>	<u>X</u>	<u> </u>	<u> </u>
(g) LIFT STATION ALARM SYSTEMS PROVIDED AND MAINTAINED	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(h) ARE LIFT STATIONS EQUIPPED WITH PERMANENT STANDBY POWER OR EQUIVALENT	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(i) IS THERE AN INFLOW INFILTRATION PROBLEM (SEPARATE SEWER SYSTEM) OR WERE THERE ANY MAJOR REPAIRS TO COLLECTION SYSTEM SINCE LAST INSPECTION	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(j) ANY COMPLAINTS RECEIVED SINCE LAST INSPECTION OF BASEMENT FLOODING	<u> </u>	<u>X</u>	<u> </u>	<u> </u>
(k) ARE ANY PORTIONS OF THE SEWER SYSTEM AT OR NEAR CAPACITY	<u> </u>	<u>X</u>	<u> </u>	<u> </u>

COMMENTS/STATUS:

Section H: Sludge Management

(a) SLUDGE MANAGEMENT PLAN (SMP)
SUBMITTED DATE 8/28/90 APPROVAL # 03-242PW NOT SUBMITTED N/A

	Yes	No	N/A	N/E
(b) SLUDGE MANAGEMENT PLAN CURRENT	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(c) SLUDGE ADEQUATELY DISPOSED (METHOD: <u>Land application</u>)	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(d) IF SLUDGE IS INCINERATED, WHERE IS ASH DISPOSED OF _____	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(e) IS SLUDGE DISPOSAL CONTRACTED (NAME: <u> </u>)	<u> </u>	<u>X</u>	<u> </u>	<u> </u>
(f) HAS AMOUNT OF SLUDGE GENERATED CHANGED SIGNIFICANTLY SINCE LAST INSPECTION	<u> </u>	<u>X</u>	<u> </u>	<u> </u>
(g) ADEQUATE SLUDGE STORAGE PROVIDED AT PLANT	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(h) LAND APPLICATION SITES MONITORED AND INSPECTED PER SMP	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(i) RECORDS KEPT IN ACCORDANCE WITH STATE AND FEDERAL LAW	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(j) ANY COMPLAINTS RECEIVED IN LAST YEAR REGARDING SLUDGE	<u> </u>	<u>X</u>	<u> </u>	<u> </u>
(k) IS SLUDGE ADEQUATELY PROCESSED (DIGESTION, DEWATERING, PATHOGEN CONTROL)	<u>X</u>	<u> </u>	<u> </u>	<u> </u>

COMMENTS/STATUS:

Section I: Self-Monitoring Program

Part 1. Flow measurement

	Yes	No	N/A	N/E
(a) PRIMARY FLOW MEASURING DEVICE PROPERLY OPERATED & MAINTAINED <u>X</u>	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
TYPE OF DEVICE: <u> </u> ULTRASONIC & PARSHALL FLUME <u>X</u> ULTRASONIC & WEIR <u> </u> WEIR <u> </u> CALCULATED FROM INFLUENT <u> </u> OTHER (Specify <u> </u>)				
(b) CALIBRATION FREQUENCY ADEQUATE (Date of last calibration <u>3/07</u>)	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(c) SECONDARY INSTRUMENTS (totalizers, recorders, etc.) PROPERLY OPERATED AND MAINTAINED	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(d) FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGES OF FLOWS	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(e) ACTUAL FLOW DISCHARGED IS MEASURED	<u>X</u>	<u> </u>	<u> </u>	<u> </u>
(f) FLOW MEASURING EQUIPMENT INSPECTION FREQUENCY: <u>X</u> DAILY <u> </u> WEEKLY <u> </u> MONTHLY <u> </u> OTHER				

COMMENTS/STATUS:

Part 2. Sampling

	Yes	No	N/A	N/E
(a) SAMPLING LOCATION(S) ARE AS SPECIFIED BY PERMIT	<u>X</u>	___	___	___
(b) PARAMETERS AND SAMPLING FREQUENCY AGREE WITH PERMIT	<u>X</u>	___	___	___
(c) PERMITTEE USES REQUIRED SAMPLING METHOD	<u>X</u>	___	___	___
(d) SAMPLE COLLECTION PROCEDURES ARE ADEQUATE	<u>X</u>	___	___	___
(i) SAMPLES REFRIGERATED DURING COMPOSITING	<u>X</u>	___	___	___
(ii) PROPER PRESERVATION TECHNIQUES USED	<u>X</u>	___	___	___
(iii) CONTAINERS AND SAMPLE HOLDING TIMES PRIOR TO ANALYSES CONFORM WITH 40 CFR 136.3	<u>X</u>	___	___	___
(e) MONITORING RECORDS (e.g., flow, pH, D.O., etc.) MAINTAINED FOR A MINIMUM OF THREE YEARS INCLUDING ALL ORIGINAL STRIP CHART RECORDINGS (e.g., continuous monitoring instrumentation, calibration and maintenance records)	<u>X</u>	___	___	___
(f) ADEQUATE RECORDS MAINTAINED OF SAMPLING DATE, TIME, EXACT LOCATION, ETC.	<u>X</u>	___	___	___

COMMENTS/STATUS:

Part 3. Laboratory

	Yes	No	N/A	N/E
GENERAL				
(a) EPA APPROVED ANALYTICAL TESTING PROCEDURES USED (40 CFR 136.3)	<u>X</u>	___	___	___
(b) IF ALTERNATE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED	___	___	<u>X</u>	___
(c) ANALYSES BEING PERFORMED MORE FREQUENTLY THAN REQUIRED BY PERMIT	<u>X</u>	___	___	___
(d) IF (c) IS YES, ARE RESULTS REPORTED IN PERMITTEE'S SELF-MONITORING REPORT	<u>X</u>	___	___	___
(e) COMMERCIAL LABORATORY USED	<u>X</u>	___	___	___
(1) PARAMETERS ANALYZED BY COMMERCIAL LAB				

Oil & Grease, Metals, ammonia & sludge

(2) LAB NAME: Ginosko

QUALITY CONTROL/QUALITY ASSURANCE

(f) QUALITY ASSURANCE MANUAL PROVIDED AND MAINTAINED	___	___	___	___
(g) SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT	___	___	___	___
(h) ADEQUATE RECORDS MAINTAINED	___	___	___	___
(i) RESULTS OF LATEST USEPA QUALITY ASSURANCE PERFORMANCE SAMPLING PROGRAM DATE : _____ SATISFACTORY ___ MARGINAL ___ UNSATISFACTORY				

COMMENTS/STATUS:

Section J: Effluent/Receiving Water Observations

OUTFALL NO.	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	VISIBLE FLOAT SOLIDS	COLOR	OTHER
001	-----	-----	-----	-----	-----	Clear	-----

COMMENTS/STATUS:

Section K: Multimedia Observations

	Yes	No	N/A	N/E
(a) ARE THERE INDICATIONS OF SLOPPY HOUSEKEEPING OR POOR MAINTENANCE IN WORK AND STORAGE AREAS OR LABORATORIES	___	<u>X</u>	___	___
(b) DO YOU NOTICE STAINING OR DISCOLORATION OF SOILS, PAVEMENT, OR FLOORS	___	<u>X</u>	___	___
(c) DO YOU NOTICE DISTRESSED (UNHEALTHY, DISCOLORED, DEAD) VEGETATION	___	<u>X</u>	___	___
(d) DO YOU SEE UNIDENTIFIED DARK SMOKE OR DUSTCLOUDS COMING FROM SOURCES OTHER THAN SMOKESTACKS	___	<u>X</u>	___	___
(e) DO YOU NOTICE ANY UNUSUAL ODORS OR STRONG CHEMICAL SMELLS	___	<u>X</u>	___	___
(f) DO YOU SEE ANY OPEN OR UNMARKED DRUMS, UNSECURED LIQUIDS, OR DAMAGED CONTAINMENT FACILITIES?	___	<u>X</u>	___	___

IF ANY OF THE ABOVE ARE OBSERVED, ASK THE FOLLOWING QUESTIONS:

- (1) WHAT IS THE CAUSE OF THE CONDITION?
- (2) IS THE OBSERVED CONDITION OR SOURCE A WASTE PRODUCT?
- (3) WHERE IS THE SUSPECTED CONTAMINANT NORMALLY DISPOSED?
- (4) IS THIS DISPOSAL PERMITTED?
- (5) HOW LONG HAS THE CONDITION EXISTED AND WHEN DID IT BEGIN?

COMMENTS/STATUS:

F. GUIDE - VISUAL OBSERVATION - UNIT PROCESS

RATING CODES: S = Satisfactory; U = Unsatisfactory; M = Marginal; IN = In Operation; OUT = Out of Operation

CONDITION OR APPEARANCE		RATING	COMMENTS
General	Grounds	S	
	Buildings	S	
	Potable Water Supply Protection	S	
	Safety Features	S	
	Bypasses	---	
	Stormwater Overflows	---	
	Alternate Power Source	OUT	Standby generator
Preliminary	Maintenance of Collection Systems	N/E	
	Pump Station	IN	2 pump stations
	Ventilation	S	
	Bar Screen	---	
	Disposal of Screenings	---	
	Comminutor	IN	At pump station before WWTP
	Grit Chamber	---	
	Disposal of Grit	---	
	Equalization Basin		
Primary	Settling Tanks	---	
	Scum Removal	---	
	Sludge Removal	---	
	Effluent	---	
Sludge Disposal	Digesters (Aerobic)	IN	2 aerated tanks (60,000 gallons)
	Temperature and pH	---	
	Gas Production	---	
	Heating Equipment	---	
	Sludge Pumps	IN	
	Drying Beds	---	
	Vacuum Filter	---	
	Disposal of Sludge	S	Land apply
	Sludge Blower	IN	3 units & 1 in use
Other	Flow Meter and Recorder	IN	Ultrasonic & weir
	Records	S	
	Lab Controls	S	
	Chemical Treatment		
Secondary-Tertiary List items as	Oxidation ditches	IN	1 NEW & 2 OLD units; 1 new one in use; good brown color & mixing
	Final settling Tanks	IN	1 NEW & 2 OLD units; 1 new one in use
Disinfection	Effluent	S	Clear effluent
	Disinfection System	IN	UV system
	Effective Dosage	---	
	Contact Time	---	
	Contact Tank	IN	
	Post Air	IN	

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PA00041*HD	May 2006	001	31616	Fecal Coliform	7D Conc	2000	3000.	5/15/2006
2PA00041*HD	January 2007	001	00530	Total Suspended Solids	30D Conc	12	19.6428	1/1/2007
2PA00041*HD	January 2007	001	00530	Total Suspended Solids	7D Conc	18	25.5	1/8/2007
2PA00041*HD	January 2007	001	00530	Total Suspended Solids	7D Conc	18	29.	1/15/2007
2PA00041*HD	January 2007	001	00530	Total Suspended Solids	30D Qty	10.9	21.2649	1/1/2007
2PA00041*HD	January 2007	001	00530	Total Suspended Solids	7D Qty	16.3	18.4991	1/8/2007
2PA00041*HD	January 2007	001	00530	Total Suspended Solids	7D Qty	16.3	43.906	1/15/2007
2PA00041*HD	January 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	3.0	3.935	1/1/2007
2PA00041*HD	January 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	12.28	1/22/2007
2PA00041*HD	January 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	2.7	4.78362	1/1/2007
2PA00041*HD	January 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	4.1	5.1476	1/15/2007
2PA00041*HD	January 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	4.1	13.9439	1/22/2007
2PA00041*HD	January 2007	001	80082	CBOD 5 day	30D Conc	10	14.	1/1/2007
2PA00041*HD	January 2007	001	80082	CBOD 5 day	7D Conc	15	17.	1/8/2007
2PA00041*HD	January 2007	001	80082	CBOD 5 day	7D Conc	15	21.	1/15/2007
2PA00041*HD	January 2007	001	80082	CBOD 5 day	7D Conc	15	17.	1/22/2007
2PA00041*HD	January 2007	001	80082	CBOD 5 day	30D Qty	9.1	13.6796	1/1/2007
2PA00041*HD	January 2007	001	80082	CBOD 5 day	7D Qty	13.6	31.794	1/15/2007
2PA00041*HD	January 2007	001	80082	CBOD 5 day	7D Qty	13.6	19.3035	1/22/2007
2PA00041*HD	October 2006	001	80082	CBOD 5 day	30D Conc	10	18.75	10/1/2006
2PA00041*HD	October 2006	001	80082	CBOD 5 day	7D Conc	15	18.	10/1/2006
2PA00041*HD	October 2006	001	80082	CBOD 5 day	7D Conc	15	29.	10/15/2006
2PA00041*HD	February 2007	001	00530	Total Suspended Solids	30D Conc	12	16.4375	2/1/2007
2PA00041*HD	February 2007	001	00530	Total Suspended Solids	7D Conc	18	19.5	2/8/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	3.0	17.705	2/1/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	24.59	2/1/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	18.82	2/8/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	20.13	2/15/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	7.28	2/22/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	2.7	6.4009	2/1/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	4.1	9.77268	2/1/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	4.1	6.41103	2/8/2007
2PA00041*HD	February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	4.1	6.85728	2/15/2007

2PA00041*HD	February 2007	001	80082	CBOD 5 day	30D Conc	10	14.4375	2/1/2007
2PA00041*HD	February 2007	001	80082	CBOD 5 day	7D Conc	15	20.75	2/1/2007
2PA00041*HD	February 2007	001	80082	CBOD 5 day	7D Conc	15	17.	2/8/2007
2PA00041*HD	January 2006	001	80082	CBOD 5 day	30D Conc	10	11.8333	1/1/2006
2PA00041*HD	January 2006	001	80082	CBOD 5 day	7D Conc	15	20.	1/15/2006
2PA00041*HD	January 2006	001	80082	CBOD 5 day	30D Qty	9.1	11.6666	1/1/2006
2PA00041*HD	January 2006	001	80082	CBOD 5 day	7D Qty	13.6	27.4223	1/15/2006
2PA00041*HD	September 2006	001	31616	Fecal Coliform	7D Conc	2000	2200.	9/22/2006
2PA00041*HD	July 2006	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	5.38	7/1/2006
2PA00041*HD	July 2006	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.5	20.	7/22/2006
2PA00041*HD	July 2006	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.9	1.7543	7/1/2006
2PA00041*HD	July 2006	001	00610	Nitrogen, Ammonia (NH3	7D Qty	1.4	6.5102	7/22/2006
2PA00041*HD	May 2007	001	31616	Fecal Coliform	7D Conc	2000	9000.	5/22/2007
2PA00041*HD	March 2007	001	00530	Total Suspended Solids	30D Conc	12	16.	3/1/2007
2PA00041*HD	March 2007	001	00530	Total Suspended Solids	7D Conc	18	28.	3/1/2007
2PA00041*HD	March 2007	001	00530	Total Suspended Solids	30D Qty	10.9	17.0798	3/1/2007
2PA00041*HD	March 2007	001	00530	Total Suspended Solids	7D Qty	16.3	35.7682	3/1/2007
2PA00041*HD	March 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	3.0	5.73	3/1/2007
2PA00041*HD	March 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	6.21	3/1/2007
2PA00041*HD	March 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	12.54	3/8/2007
2PA00041*HD	March 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	2.7	3.88866	3/1/2007
2PA00041*HD	March 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	4.1	7.05146	3/1/2007
2PA00041*HD	March 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	4.1	4.50907	3/8/2007
2PA00041*HD	March 2007	001	80082	CBOD 5 day	30D Conc	10	11.5625	3/1/2007
2PA00041*HD	March 2007	001	80082	CBOD 5 day	7D Conc	15	19.75	3/1/2007
2PA00041*HD	March 2007	001	80082	CBOD 5 day	30D Qty	9.1	12.2302	3/1/2007
2PA00041*HD	March 2007	001	80082	CBOD 5 day	7D Qty	13.6	25.3595	3/1/2007
2PA00041*HD	July 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	1.9225	7/1/2007
2PA00041*HD	July 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.5	6.1	7/1/2007
2PA00041*HD	July 2007	001	00610	Nitrogen, Ammonia (NH3	7D Qty	1.4	2.8168	7/1/2007