



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Marion County  
Sypris Technologies  
NPDES Permit

November 14, 2007

Mr. Lonnie Bulter  
Sypris Technologies Marion LLC  
13267 State Route 68 South  
Kenton, Ohio 43326

Dear Mr. Bulter:

This will acknowledge our October 4, 2007, compliance inspection at your Marion facility. We appreciate your assistance in providing information regarding the operation of the treatment facilities.

The oil/water separator appeared to be working. No oil sheen was noted on the pond. Some weeds were growing on the pond embankments and must be removed to maintain their structural integrity.

At the time of the inspection, there was no discharge from the pond. Please note that your NPDES permit became effective on October 1, 2005 and will expire on September 30, 2010. When a discharge occurs from the pond, it must be sampled in accordance with the NPDES permit.

Our cursory review of your self-monitoring reports (1/2006 to 9/2007) for this facility showed one effluent violation. Please refer to the enclosed violation table.

Please call our office if you have any questions or comments.

Yours truly,

Jason Ko  
Division of Surface Water

/llr

pc: DSW-NWDO File

# NPDES COMPLIANCE INSPECTION REPORT

## Section A: National Data System Coding

Permit #	NPDES	Yr/Mo/Day	Inspection Type	Inspector	FacType
<u>21100104</u>	<u>OH0126594</u>	<u>2007/10/4</u>	<u>C</u>	<u>S</u>	<u>1</u>

## Section B: Facility Data

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Sypris Technologies Marion LLC 1550 Marion Agosta Road Marion, OH 43302	11:00 A.M.	10/01/2005
	Exit Time	Permit Expiration Date
	11:30 A.M.	9/30/2010

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Mr. Lonnie Bulter, Environmental Health & Safety Coordinator Mr. John Rhyne, Corporate Safety	(419) 674-5290

Name, Address and Title of Responsible Official	Phone Number
Lonnie Bulter, Environmental Health & Safety Coordinator Sypris Technologies Marion LLC 13267 State Route 68 South Kenton, OH 43326	(419) 674-5290

## Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

<u>S</u> Permit	<u>--</u> Flow Measurement	<u>-</u> Pretreatment
<u>S</u> Records/Reports	<u>--</u> Laboratory	<u>--</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>--</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>--</u> Sludge Storage/Disposal	<u>-</u> Other

## Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

- \* No discharge from the pond
- \* No oil sheen noted on the pond
- \* The NPDES permit became effective on 10/1/2005 and will expire on 9/30/2010
- \* Remove weeds on pond embankment

  
 Jason Ko

Name(s) and Signature(s) of Inspector(s)

11/9/07

Date

Ohio EPA, Northwest District Office

  
 Elizabeth A. Wick, P.E.

Name and Signature of Reviewer

11/8/07

Date

Ohio EPA, Northwest District Office

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
21100104*BD	March 2007	001	00530	Total Suspended Solids	30L Conc	30	37.	3/1/2007