



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



July 31, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Joseph Binder, III  
Apollo Mobile Home Park  
4105 1/2 West State Route 20  
Gibsonburg, Ohio 43431

Sandusky County  
Apollo Mobile Home Park  
Community PWS  
PWS ID: OH7200012  
STU ID: 7257898

Dear Mr. Binder:

The Public Water System serving Apollo Mobile Home Park is in violation of the Ohio Administrative Code (OAC) for failing to comply with the operational requirements of OAC 3745-83-01 during the month of June, 2012.

1. In violation of OAC 3745-83-01(F)(5)(a)(i), the public water system failed to report iron at the plant tap on a weekly basis. There were three (3) weeks during the month in which no analysis was reported.
2. In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. The concentration of iron in the only sample reported in June 2012 was 1.08 mg/L.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:


- a. Public water systems shall use the monitoring required by OAC 3745-83-01(F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- b. A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Mr. Joseph Binder, III  
July 31, 2012  
Page 2

If you have any questions regarding this letter, please contact me at 419-373-3102 or via email at [Kim.Burnham@epa.state.oh.us](mailto:Kim.Burnham@epa.state.oh.us). Beginning in September 2012, questions should be addressed to my colleague, Janis D'Amico at 419-373-3108 or via email at [Janis.Damico@epa.state.oh.us](mailto:Janis.Damico@epa.state.oh.us).

Sincerely,



Kimberly K. Burnham, R.S.  
Division of Drinking and Ground Waters

/llr

pc: Sandusky County Health Department  
Eric Kurfis, Clean Water Service, Inc.  
File: DDAGW – NWDO

ec: Janis D'Amico, DDAGW – NWDO