



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



July 31, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Rod Opelt
Lindsey Village Water
240 South Main Street
P. O. Box 364
Lindsey, Ohio 43442

Sandusky County
Lindsey Village Water
Community PWS
PWS ID: OH7200512
STU ID: 7261999

Dear Mr. Opelt:

The Public Water System serving Lindsey Village Water is in violation of the Ohio Administrative Code (OAC) for failing to comply with the operational requirements of OAC 3745-83-01 during the month of June, 2012.

1. In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There were 30 days during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:


- a. Public water systems shall use the monitoring required by OAC 3745-83-01(F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- b. A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Mr. Rod Opelt
July 31, 2012
Page 2

If you have any questions regarding this letter, please contact me at 419-373-3102 or via email at Kim.Burnham@epa.state.oh.us. Beginning in September 2012, questions should be addressed to my colleague, Janis D'Amico at 419-373-3108 or via email at Janis.Damico@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

//lr

pc: Sandusky County Health Department
Thomas Frey, Sandusky County Sanitary Engineer Department
File: DDAGW – NWDO

ec: Janis D'Amico, DDAGW – NWDO