



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



NOTICE OF VIOLATION – ACTION REQUIRED

August 13, 2012

Mr. Steven R. Ureel
Hillcrest Estates Mobile Home Court
1120 North Main Street
Rochester, Michigan 48307

Hardin County
Hillcrest Estates Mobile Home Court
Community PWS
PWS ID: OH3301212
STU ID: 3354893


Dear Mr. Ureel:

The Public Water System serving Hillcrest Estates Mobile Home Court is in violation of the Ohio Administrative Code (OAC) for failing to comply with the operational requirements of OAC 3745-83-01 during the month of June, 2012.

In violation of OAC 3745-83-01(F)(5)(a)(i), the public water system failed to report iron at the plant tap on a weekly basis. There were three (3) weeks during the month in which no analysis was reported.

If you have any questions regarding this letter, please contact me at (419) 373-3102 or via email at Kim.Burnham@epa.state.oh.us.

Sincerely,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

/cg

pc: Hardin County Health Department
Philip Epley
File: DDAGW – NWDO

