



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



August 15, 2012

Mr. Rick Rufenacht
Rainbow Promise Childcare and Preschool
561 Carter Road
Defiance, Ohio 43512

Defiance County
Rainbow Promise Childcare and
Preschool
Non-Transient Non-Community PWS
PWS ID: OH2035412

Subject: Rescinding Violation – TCR

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on July 27, 2012, for the monitoring period of second quarter 2012. The sample was collected on June 20, 2012, but the result was not reported to our office until July 31, 2012.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at (419) 373-3048.

Sincerely,

Ralph J. Baker
Division of Drinking and Ground Waters

/cg

pc: Defiance County Health Department
DDAGW – NWDO

