



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ottawa County
Blue Moon Apartments
NPDES Permit

December 28, 2009

Mr. Don Gruber
21530 Moline-Martin
Genoa, Ohio 43430

Dear Mr. Gruber:


On December 17, 2009, an inspection was made of the wastewater treatment facilities serving the Blue Moon Apartments. In general, both operation and maintenance appeared improved since my last inspection. At the time of my visit, all major treatment components were in operation and a clear final effluent was observed in the chlorine contact tank.

Recent drainage improvements at the site have resulted in improved plant operations. The west clay building sewer was replaced with PVC pipe and ODOT also completed a project along SR 163 which redirected drainage off the property.

NPDES discharge monitoring reports are being received in a timely manner and indicated numerous violations this year. Enclosed is a copy of the violations to review with your operator. The noted drainage improvements should improve compliance going forward.

Enclosed is my completed inspection report. If you have any questions, please call me at (419) 373-3020 or email at rick.zuzik@epa.state.oh.us.

Sincerely,



Richard A. Zuzik, MSE
Division of Surface Water

/lb
pc: Ottawa County Health Dept.
Eastwood Environmental
NWDO File