



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Ottawa County
Middle Bass Island
Middle Bass Club
NPDES Permit

August 24, 2010

Mr. Jaime Hovsepian
125 Artesian Drive
Ashland, OH 44805

Dear Mr. Hovsepian:

On August 2, 2010, an inspection was made of the wastewater treatment facilities serving The Middle Bass Club on Middle Bass Island. At the time of my visit all major treatment components were in operation, however, the transfer pipe between tanks was leaking profusely and mixed liquor was running over the ground. Jarrod was notified and informed you of my findings. I was later informed that the plant had been pumped down and the collapsed pipe had been repaired.

I will attempt to make one more visit to Middle Bass Island this year to observe the plant under normal operating conditions.

If you have any questions, please call me at (419) 373-3020, or email at rick.zuzik@epa.state.oh.us.

Sincerely,



Richard A. Zuzik, MSE
Division of Surface Water

/lb

pc: Ottawa Co. Health Department
Eastwood Environmental

~~NPDES file~~