



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Paulding County  
Village of Latty  
NPDES Permit

October 5, 2010

Mayor and Council  
Village of Latty  
P.O. Box 86  
Latty, Ohio 45855-0086


Dear Mayor and Council:

On September 17, 2010, I met with representatives of the Village of Latty and Industrial Fluid Management, Inc. (IFM), to inspect the Village's Wastewater Treatment Plant (WWTP). At the time of inspection, the plant was discharging and the effluent appeared clear.

The plant's pump station steel structure was replaced with fiberglass and new hardware. It was indicated that one of the SBR units had lost its biomass due to excessive dilution flow and is being reseeded. Chlorination and de-chlorination tablets were present in the disinfection tank. The flow meter was out and the influent pump rate and time were being used to measure flow.

I will be conducting a follow-up inspection in the near future to evaluate the plant operation and maintenance necessary to achieve compliance. If you have any questions, please contact me at [naajyabdullah@epa.state.oh.us](mailto:naajyabdullah@epa.state.oh.us) or (419) 373-3017.

Sincerely,

  
Naajy Abdullah, P.E.  
Division of Surface Water

/lb

pc: ~~NWDO-DSW-File~~  
Tommy Roth, IFM, Inc