



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Paulding County
Village of Latty
NPDES Permit

March 31, 2011

Mayor and Council
Village of Latty
P O. Box 86
Latty, Ohio 45855

Dear Mayor and Council:


On March 24, 2011, I conducted an inspection the wastewater treatment plant (WWTP) serving the Village of Latty. Ms. Kasey Carlisle, of Industrial fluid Management (IFM), the operator of the WWTP, was present and provided information regarding the plant.

At the time of inspection, both SBR units were in service and the effluent appeared typical. It was indicated that the post air blower will be replaced soon. The existing sludge holding tank is out of use due to structural deterioration and is planned to be replaced.

The automatic sampler is not used and only grab samples are collected for compliance determination. Please note that the permit requires the collection of composite samples for certain parameters. If an automatic sampler is not available, multiple grab samples would be acceptable until an automatic sampler is provided.

If you have any questions regarding the above please contact me at naajy.abdullah@epa.state.oh.us or (419) 373-3017.

Sincerely,


Naajy Abdullah, P.E.
Division of Surface Water

/llr

pc: Kasey Carlisle, IFM
