



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Paulding County
Village of Oakwood
Oakwood WWTP

October 5, 2010

Mr. Timothy Phillips
Operator-in-charge
Village of Oakwood
228 North First Street
Oakwood, OH 45873

Dear Mr. Phillips:

On September 14, 2010, I met with you to conduct an inspection of the Wastewater Treatment Plant serving the Village of Oakwood.

The plant consists of three (3) stabilization lagoons operated in series. At the time of inspection, the third lagoon was discharging. The discharged water appeared typical. It was indicated that you discharge once a year when the flow reaches a designated level in the third lagoon and the discharge would be continuous and lasts more than thirty days.

As I indicated to you during the inspection, the flow should be monitored during the discharge period in accordance with the frequency specified in the Village's discharge permit.

If you have any questions, please contact me at naajy.abdullah@epa.state.oh.us or (419) 373-3017.

Sincerely,


Naajy Abdullah, P.E.
Division of Surface Water

/lb

~~RC-NWDO-DSWIFile~~