

**Environmental
Protection Agency**

Tom Swickard, Governor
Lee Fisher, Lt. Governor
Chris Kozlowski, Director

May 19, 2010

Ms. Prue Dana, Mayor
City of Oxford
101 East High Street
Oxford, Ohio 45056-1887

Re: Butler County, City of Oxford WWTP, NPDES Permit Violations

Dear Ms. Dana:

We have received your Monthly Operating Reports covering the month of February 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0026930; OEPA Permit # 1PD00007*LD). The specific instance of noncompliance was as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
February 2010	TSS	Weekly	kg/day	716	755

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

NPDES Permit violations may also be reported in accordance to the new Ohio EPA reporting requirements. These reporting requirements are addressed at the following Ohio EPA website: http://www.epa.state.oh.us/dsw/permits/24-hour_Report_FactSheet.pdf.

Ms. Prue Dana, Mayor
May 19, 2010
Page 2

If you have any questions regarding the above, please contact me at (937) 285 - 6096.

Sincerely,

A handwritten signature in cursive script, appearing to read "Ned Sarle".

Ned Sarle
Division of Surface Water
Permit Section

ec: Jeff Ratliff, City of Oxford