



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 28, 2008

Mr. James Geyer, Owner  
JGR Properties, Inc.  
P.O. Box 354  
Oxford, Ohio 45056

Re: Butler County, Millville MHP, NPDES Permit Violations

Dear Mr. Geyer:

We have reviewed your Monthly Operating Reports (MORs) covering the March of 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0133736; OEPA Permit # 1PV00124\*AD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
March 2008	DO	Daily	mg/l	6.0	4.5

Effluent Monitoring Violations						
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	
March 2008	001	TSS	1/Quarter	1	0	
March 2008	001	Ammonia	1/Quarter	1	0	
March 2008	001	CBOD5	1/Quarter	1	0	
March 2008	001	pH	1/Quarter	1	0	

In addition, the Ohio EPA commented on the Permit to Install application submitted for the WWTP upgrade. Please address these comments immediately.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mr. James Geyer  
April 28, 2008  
Page 2

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle  
Division of Surface Water  
Permit Section

cc: Duane Boswell, WWTP Operator