



State of Ohio Environmental Protection Agency

Geyer

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 23, 2008

Mr. James Geyer, Owner
JGR Properties, Inc.
P.O. Box 354
Oxford, Ohio 45056

Re: Butler County, Millville MHP, NPDES Permit Violations

Dear Mr. Geyer:

We have reviewed your Monthly Operating Reports (MORs) covering the months of March through September 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0133736; OEPA Permit # 1PV00124*AD and 1PV00124*BD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
March 2008	TSS	Monthly	mg/l	12	99
March 2008	TSS	Monthly	kg/day	0.14	1.4
March 2008	Ammonia	Monthly	mg/l	3.0	28
March 2008	Ammonia	Monthly	kg/day	0.034	0.40
March 2008	CBOD5	Monthly	mg/l	10	210
March 2008	CBOD5	Monthly	kg/day	0.11	3.0
March 2008	DO	Daily	mg/l	6.0	4.5
March 2008	TSS	Weekly	mg/l	18	99
March 2008	TSS	Weekly	kg/day	0.20	1.4
March 2008	Ammonia	Weekly	mg/l	4.5	28
March 2008	Ammonia	Weekly	kg/day	0.051	0.40
March 2008	CBOD5	Weekly	mg/l	15	210
March 2008	CBOD5	Weekly	kg/day	0.17	3.0
March 2008	pH	Daily	S.U.	6.5	5.0
June 2008	TSS	Monthly	mg/l	12	98
June 2008	TSS	Monthly	kg/day	0.14	0.50
June 2008	Ammonia	Monthly	mg/l	1.0	35

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
June 2008	Ammonia	Monthly	kg/day	0.011	0.18
June 2008	Fecal Coliform	Monthly	#/100ml	1000	190000
June 2008	DO	Daily	mg/l	6.0	4.5
June 2008	TSS	Weekly	mg/l	18	98
June 2008	TSS	Weekly	kg/day	0.20	0.50
June 2008	Ammonia	Weekly	mg/l	1.5	35
June 2008	Ammonia	Weekly	kg/day	0.017	0.18
June 2008	Fecal Coliform	Weekly	#/100ml	2000	190000
June 2008	pH	Daily	S.U.	6.5	4.5
August 2008	DO	Daily	mg/l	6.0	5.2

Effluent Monitoring Violations					
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported
August 2008	001	TSS	1/Quarter	1	0
August 2008	001	Ammonia	1/Quarter	1	0
August 2008	001	CBOD5	1/Quarter	1	0
August 2008	001	pH	1/Quarter	1	0
August 2008	001	Fecal Coliform	1/Quarter	1	0
August 2008	001	Chlorine	1/Quarter	1	0

In addition, the Ohio EPA approved the Permit to Install for the WWTP upgrade. Please indicate when this construction will be started.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation is not satisfactory and we request, within ten days of receipt of this letter, written information as to what additional steps you take to prevent further occurrences. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Mr. James Geyer
October 23, 2008
Page 3

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in black ink, appearing to read "Ned Sarle". The signature is fluid and cursive, with a long horizontal stroke at the end.

Ned Sarle
Division of Surface Water
Permit Section

cc: Duane Boswell, WWTP Operator