



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 26, 2011

Bill Young
965 Dayton Avenue
Springfield, OH 45506

CERTIFIED LETTER

**Re: Springfield Beckley, Clark County
Self-Monitoring Report NOV – January through April 2011
NPDES Permit No. 1PS00009/OH0108839**

Dear Mr. Young:

We have received your self-monitoring reports covering the months of January through April 2011 for the above-referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and deficiencies were as follows:

Final Effluent Limitation Violation for Outfall 001					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2011	Total Suspended Solids	30D Conc	12.0	4.5416	1/1/2011
January 2011	Total Suspended Solids	7D Conc	18.0	55.	1/1/2011
January 2011	Total Suspended Solids	7D Conc	18.0	22.	1/15/2011
January 2011	Total Suspended Solids	30D Qty	3.18	.97018	1/1/2011
January 2011	Total Suspended Solids	7D Qty	4.78	1.8912	1/1/2011
January 2011	Total Suspended Solids	7D Qty	4.78	.79181	1/15/2011
February 2011	Total Suspended Solids	30D Conc	12.0	0.6363	2/1/2011
February 2011	Total Suspended Solids	7D Conc	18.0	6.1666	2/1/2011
February 2011	Total Suspended Solids	7D Conc	18.0	86.5	2/8/2011
February 2011	Total Suspended Solids	7D Conc	18.0	28.25	2/15/2011
February 2011	Total Suspended Solids	7D Conc	18.0	0.8333	2/22/2011
February 2011	Total Suspended Solids	30D Qty	3.18	5.8722	2/1/2011
February 2011	Total Suspended Solids	7D Qty	4.78	0.6497	2/1/2011
February 2011	Total Suspended Solids	7D Qty	4.78	4.5785	2/8/2011
February 2011	Total Suspended Solids	7D Qty	4.78	.80788	2/15/2011
February 2011	Total Suspended Solids	7D Qty	4.78	3.0979	2/22/2011
February 2011	CBOD 5 day	7D Qty	3.98	.27579	2/22/2011
March 2011	Total Suspended Solids	30D Conc	12.0	3.2692	3/1/2011
March 2011	Total Suspended Solids	7D Conc	18.0	2.8333	3/1/2011
March 2011	Total Suspended Solids	30D Qty	3.18	.79218	3/1/2011
March 2011	Total Suspended Solids	7D Qty	4.78	3.1718	3/1/2011
March 2011	Total Suspended Solids	7D Qty	4.78	1.7089	3/8/2011
April 2011	Total Suspended Solids	30D Conc	12.0	4.6923	4/1/2011
April 2011	Total Suspended Solids	7D Conc	18.0	3.6666	4/15/2011
April 2011	Total Suspended Solids	30D Qty	3.18	1.5909	4/1/2011
April 2011	Total Suspended Solids	7D Qty	4.78	30.2251	4/15/2011
April 2011	Total Suspended Solids	7D Qty	4.78	9.31362	4/22/2011

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov


Mr. Young
Page 2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Ohio EPA acknowledges that the City is planning to connect the satellite WWTP to the main WWTP in approximately 30 months; however, we need additional information on the operational and/or maintenance actions that have been taken or will be taken to bring the WWTP into compliance with final effluent limits. We consider this WWTP to be in significant noncompliance.

If you have any questions regarding the above, please contact me at (937) 285-6104.

Respectfully,

A handwritten signature in cursive script that reads "Sandra D. Leibfritz".

Sandra D. Leibfritz
Division of Surface Water

cc: Clark County Health Department

7007 0220 0001 2491 6915

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com®

OFFICIAL USE

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
Here
5/26/2011

Sent To Bill Young

Street, Apt. No.,
or PO Box No. 965 Norton Ave.

City, State, ZIP+4 Springfield Oh 45506