



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Ashland County
Ashland-Nankin Waterline
Extension
Development
Construction
Storm Water

August 15, 2011

Mr. Tim Mahoney
Rural Lorain County Water Authority
42401 State Route 303
P. O. Box 567
Lagrange, Ohio 44050

Mr. Ted Mann
Elite Excavating Company of Ohio, Inc.
P. O. Box 290
Ontario, Ohio 44862

Dear Mr. Mahoney & Mr. Mann:

On June 29, 2011, I inspected Ashland-Nankin Waterline Extension on State Route 58, north and south of Nankin and other roads, in Montgomery and Orange Townships. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC01467*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that the project on State Route 58, north and south of Nankin and other roads is complete. A Notice of Termination **must be filed** to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

1. Final stabilization has been established on all areas of the site for which the permittees are responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized

Mr. Tim Mahoney
Mr. Ted Mann
August 15, 2011
Page 2

2. Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Your site appears to meet the conditions mentioned above. If you believe the same is true please file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be filed with Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact Lynette Hablitzel, Ohio EPA Division of Surface Water at (419) 373-3009.

Sincerely,



Brian McGlown
Division of Surface Water
Storm Water Program

/llr

pc: DSW-NWDO File
Cathy Berg, District Administrator, Ashland County SWCD
Edward J. Meixner, P.E., P.S., Ashland County Engineer