



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Ashland County
Jeromesville WWT System
Construction
Storm Water

August 16, 2011

Mr. Ed Blough
Village of Jeromesville
81 South High Street
Jeromesville, Ohio 44840

Dear Mr. Blough:

On June 29, 2011, I inspected Jeromesville WWT System throughout the Village of Jeromesville. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC00819*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Ohio EPA has no record of other permittees for this site.

It appears that the project throughout the village is complete. The village initially did not contain sanitary sewers and this project was the installation of a sanitary sewer system. A Notice of Termination **must be filed** to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


1. Final stabilization has been established on all areas of the site for which the permittees are responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized
2. Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Ed Blough
August 16, 2011
Page 2

Your site appears to meet the above conditions. If you believe the same is true, please file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be filed with Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact Lynette Hablitzel, Ohio EPA Division of Surface Water at (419) 373-3009.

Sincerely,



Brian McGlown
Division of Surface Water
Storm Water Program

/llr

ps: ~~DSW-NWDO File~~