



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 8, 2010

RE: CUYAHOGA COUNTY
EAST BRANCH- ROCKY RIVER BASIN
CITY OF BEREA
SR 237 BETWEEN SHELDON ROAD AND 3RD STREET

Mr. Randall Over
5500 Transportation Boulevard
Garfield Heights, OH 44125

Dear Mr. Over:

On June 29, 2010, Ohio EPA conducted an inspection of the State Route 237 project located between Sheldon Road and 3rd Street, City of Berea, Cuyahoga County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC03529*AG. I was accompanied by Mark Kollin of ODOT and Ryan Simon of Great Lakes Construction Company. The inspection documented the following:

- Most of the earth-disturbing activities along SR 237 appear to be complete. All areas at final grade have been stabilized. The remaining construction consists of bridge construction and concrete placement.
- Inlet protection has been installed in accordance with the site's storm water pollution prevention plan (SWP3). Dandy bags were observed on all inlets within the site.
- Silt fence has been installed in accordance with the site's SWP3.
- Stabilize all areas that will remain idle for 21 days or longer or that are at final grade.
- Exfiltration trenches have been installed in accordance with the site's post construction plans. Some of the exfiltration trenches are in need of maintenance. Maintain exfiltration trenches as necessary until operation and maintenance of the exfiltration trenches is transferred.

Please submit a copy of the site's post construction plans within 14 days of receiving this letter. Any above deficiencies must be addressed within 14 days of receiving this letter. Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,

Sean Green
Assistant to the District Engineer
Division of Surface Water

SG:bo

cc: Ryan R. Simon, P.E., c/o The Great Lakes Construction Company
Dan Bogoevski, Ohio EPA, DSW, NEDO