



**Environmental
Protection Agency**

Gov. Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

August 16, 2010

RE: GEauga COUNTY
BIG CREEK BASIN
FIFTH AVENUE REALIGNMENT
AND CENTER STREET WIDENING

Mr. David A. Lelko
111 Water Street
Chardon, OH 44024

Dear Mr. Lelko:

On August 12, 2010, Ohio EPA conducted a follow-up inspection of the Fifth Avenue Realignment and Center Street Widening project located at the intersection of Fifth Avenue and Center Street, City of Chardon, Geauga County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04228*AG. The inspection documented that the project has been completed. All areas appeared stabilized. You are eligible to terminate the NPDES Permit once all of the following criteria are met:

1. All temporary erosion and sediment controls are removed and disposed.
2. All trapped sediments have been permanently stabilized to prevent further erosion.
3. All soil disturbing activities on this site have been completed.
4. A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing a Notice of Termination (NOT) which can be obtained from:

<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,

Sean Green
Assistant to the District Engineer
Division of Surface Water

SG/mt