

**Environmental
Protection Agency**

_____, Governor
_____, Lt. Governor
_____, Director

June 25, 2010

RE: GEAUGA COUNTY
GRISWOLD CREEK BASIN
RUSSELL TOWNSHIP
LAUREL SCHOOL

Ms. Mary Ann Pellerano
1 Lyman Circle
Shaker Heights, Ohio 44122

Dear Ms. Pellerano:

On June 22, 2010, Ohio EPA conducted an inspection of the Laurel School project, located at 7420 Fairmount Road, Russell Township, Geauga County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04528*AG. The inspection revealed that the building construction has been completed. All perimeter areas appeared stabilized or ready to be stabilized. You are eligible to terminate the NPDES Permit once all of the following criteria are met:

1. All temporary erosion and sediment controls are removed and disposed.
2. All trapped sediments have been permanently stabilized to prevent further erosion.
3. All soil disturbing activities on this site have been completed.
4. A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing a Notice of Termination (NOT) which can be obtained from:

http://www.epa.ohio.gov/portals/35/documents/NOT_app_fis.pdf

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,



Sean Green
Assistance to the District Engineer
Division of Surface Water

SG/mt

cc: Dan Bogoevski, Ohio EPA, DSW, NEDO
Gauga SWCD