



**Environmental
Protection Agency**

Tim Wines, Governor
Lee Fisher, Lt. Governor
Dave Lonsdale, Director

June 24, 2010

RE: LORAIN COUNTY
RIDGEWAY DITCH BASIN
CITY OF ELYRIA
LORAIN COUNTY COMMUNITY
COLLEGE CENTER RENOVATIONS

Mr. Robert Flyer
1005 N. Abbe Road
Elyria, Ohio 44035

Dear Mr. Flyer:

On June 15, 2010, Ohio EPA conducted an inspection of the Lorain County Community College Renovations project, located at 1005 N. Abbe Road, City of Elyria, Lorain County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04256*AG. I was accompanied by Chris Moody of Ohio EPA. The inspection revealed that the building construction has been completed. All perimeter areas appeared stabilized or ready to be stabilized. You are eligible to terminate the NPDES Permit once all of the following criteria are met:

1. All temporary erosion and sediment controls are removed and disposed.
2. All trapped sediments have been permanently stabilized to prevent further erosion.
3. All soil disturbing activities on this site have been completed.
4. A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing a Notice of Termination (NOT) which can be obtained from:

http://www.epa.ohio.gov/portals/35/documents/NOT_app_fis.pdf

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,

Sean Green
Assistance to the District Engineer
Division of Surface Water

SG/mt

cc: Mukund Moghe, City of Elyria Engineer
Dan Bogoevski, Ohio EPA, DSW, NEDO

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov