

**Environmental
Protection Agency**

**Governor
Lt. Governor
Director**

July 19, 2011

RE: LORAIN COUNTY
CITY OF ELYRIA
MCDONALD'S
CONSTRUCTION STORM WATER

McDonald's Corporation
2 Easton Oval # 200
Columbus, OH 43219

To Whom it May Concern:

On July 13, 2011, I performed an inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC04844*AG. Our records indicate that McDonald's Corporation was granted coverage under the NPDES permit on March 22, 2010.

It appears that construction activities are complete and the site has been stabilized. Please be aware that NPDES permit coverage must be terminated within 45 days of when the site reaches final stabilization. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover (i.e., evenly distributed, without large bare areas) has reached a growth density of 70% or greater on all unpaved areas and areas not covered by permanent structures. Equivalent stabilization measures such as the use of landscape mulches, rip-rap or gabions may be employed, where appropriate, in lieu of vegetation. In addition, all temporary erosion and sediment control practices must be removed and disposed and all sediment trapped by these practices must be permanently stabilized.


In addition, post-construction water quality best management practices (post-construction BMPs) must be installed and a long-term maintenance plan must be provided to the party that will be responsible for long-term maintenance of those practices, e.g., homeowners' association. Post-construction BMPs are permanent site features that will remain in perpetuity to improve the quality of storm water runoff from the development site. Examples of post-construction BMPs include, but are not limited to, extended detention basins, bioretention cells (or "rain gardens"), sand filters, permeable pavement and enhanced swales. In some cases post-construction BMPs include non-structural preservation areas such as riparian setbacks and conservation easements.

Please review your site to determine if it has reached final stabilization and ensure that post-construction BMPs have been installed. *Please consult with Mukund Moghe, MS4 Program Manager to make this determination.* If you determine that your site has reached final stabilization, you must submit a Notice of Termination (NOT) to Ohio EPA to terminate NPDES permit coverage. The form and instructions are available on our website at www.epa.ohio.gov/dsw/storm/stormform.aspx. If you determine that your site does not yet qualify for an NOT, please provide me with a letter of explanation indicating why NPDES permit coverage cannot yet be terminated. Please submit the NOT or letter of explanation no later than August 1, 2011.

MCDONALD'S CORPORATION
JULY 19, 2011
PAGE 2

If you have any questions, please contact me at (330) 963-1128.

Sincerely,

A handwritten signature in black ink, appearing to read "Tim McParland". The signature is written in a cursive style with a large, looping initial "T".

Tim McParland
Assistant to the District Engineer
Division of Surface Water

TM:bo

pc: Mukund Moghe, City of Elyria, Engineer & MS4 Program Manager
William Grace, City of Elyria, Mayor
Lorain SWCD