



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 6, 2010

RE: LORAIN COUNTY
SQUIRES SCHRAMM DITCH BASIN
NEW RUSSIA/ CARLISLE TOWNSHIPS
RUSSIA ROAD BETWEEN SR 58 AND OBERLIN

Mr. William Holtzman
247 Hadaway Street
Elyria, OH 44035

Dear Mr. Holtzman:

On June 15, 2010, Ohio EPA conducted an inspection of the Russia Road construction project located between State Route 58 and Oberlin, New Russia and Carlisle Townships, Lorain County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04554*AG. I was accompanied by Chris Moody of Ohio EPA. The inspection documented the following:

- Silt fence appeared to be torn and damaged in some areas. Repair or reinstall silt fence in accordance with the site's storm water pollution prevention plan (SWP3).
- Much of the project appears to be complete. Stabilize all areas that are at final grade or that will remain idle for 21 days or longer.

You are eligible to terminate the NPDES Permit once all of the following criteria are met:

1. All temporary erosion and sediment controls are removed and disposed.
2. All trapped sediments have been permanently stabilized to prevent further erosion.
3. All soil disturbing activities on this site have been completed.
4. A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing a Notice of Termination (NOT) which can be obtained from:

http://www.epa.ohio.gov/portals/35/documents/NOT_app_fis.pdf

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,

Sean Green
Assistant to the District Engineer
Division of Surface Water

SG:bo

cc: Dan Bogoevski, Ohio EPA, DSW, NEDO