

**Environmental
Protection Agency**

_____, Governor
_____, Lt. Governor
_____, Director

June 24, 2010

RE: LORAIN COUNTY
BLACK RIVER BASIN
CITY OF LORAIN
HAWTHORNE ELEMENTARY SCHOOL

Mr. Steve Gilmore
2350 Pole Avenue
Lorain, Ohio 44052

Dear Mr. Gilmore:

On June 15, 2010, Ohio EPA conducted an inspection of the Hawthorne Elementary School project, located at 1600 East 31st Street, City of Lorain, Lorain County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04300*AG. I was accompanied by Chris Moody of Ohio EPA. The inspection revealed that the building construction has been completed. All perimeter areas appeared stabilized or ready to be stabilized. You are eligible to terminate the NPDES Permit once all of the following criteria are met:

1. All temporary erosion and sediment controls are removed and disposed.
2. All trapped sediments have been permanently stabilized to prevent further erosion.
3. All soil disturbing activities on this site have been completed.
4. A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing a Notice of Termination (NOT) which can be obtained from:

http://www.epa.ohio.gov/portals/35/documents/NOT_app_fis.pdf

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,



Sean Green
Assistance to the District Engineer
Division of Surface Water

SG/mt

cc: Dale Vandersommen, City of Lorain
Dan Bogoevski, Ohio EPA, DSW, NEDO