



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Konecki, Director

July 19, 2010

RE: MAHONING COUNTY
TURKEY BRANCH CREEK BASIN
ELLSWORTH TOWNSHIP
WESTERN RESERVE K-12 SCHOOL

Mr. Michael Fagan
13850 Akron-Canfield Road
Berlin Center, OH 44401

Dear Mr. Fagan:

On July 15, 2010, Ohio EPA conducted an inspection of the Western Reserve K-12 School project, located at 13850 Akron-Canfield Road, Ellsworth Township, Mahoning County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04619*AG. The inspection documented the following:

- At the time of inspection, two of the sediment basins were being installed. Ensure the sediment basins are installed per the site's SWP3.
- Dust control appears to be a major issue on-site. Minimize dust generation through watering activities and street sweeping.
- Silt fence was observed to be installed correctly and in working condition. Maintain silt fence in accordance with the site's storm water pollution prevention plan (SWP3).
- Stabilize all areas that will remain idle for 21 days or longer or that are at final grade.

Any above deficiencies must be addressed within 14 days of receiving this letter. Should you have any questions regarding this matter, please contact me at your earliest convenience by phone at (330) 963-1128, or by email at Sean.Green@epa.state.oh.us

Sincerely,

Sean Green
Assistant to the District Engineer
Division of Surface Water

SG/mt

cc: Mark J. Dodd, Hammond Construction
Mahoning SWCD