



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 20, 2011

RE: Medina County  
Lafayette Township  
University of Akron Medina Campus  
NPDES Permit No: OHC000002  
Ohio EPA Permit No: 3GC02280\*AG  
Construction Storm Water Inspection

Mr. David Pierson  
Ruhlin Company  
6931 Ridge Road  
P.O. Box 190  
Sharon Center, OH 44274

Dear Mr. Pierson:

On May 11, 2011, Ohio EPA conducted an inspection of University of Akron - Medina Campus, located at 6300 Technology Lane, Lafayette Township, Medina County (site). Ohio EPA records indicate that the site is covered by General National Pollutant Discharge Elimination System Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC02280\*AG.

The inspection documented that construction activities at the site appear to have been completed. Part IV.B.2. of the General Storm Water Permit requires a Notice of Termination (NOT) form, enclosed, to be submitted for the site within 45 days of completing all permitted land disturbance activities.

Within fourteen days of receiving this inspection letter, you must perform one of the following actions:

1. Submit the following information to Ohio EPA:
  - A. Documentation (water quality volume calculations, engineered plans, etc.) on how the site has satisfied the post-construction storm water management requirements established within Part III.G.2.e of the General Storm Water Permit;
  - B. Documentation that all sediment control practices (i.e. installed silt fence) have been removed from the site. During the inspection, Ohio EPA documented that silt fence installed in areas where the site has been permanently stabilized; and

Mr. David Pierson  
University of Akron Medina Campus  
May 20, 2011  
Page 2

- C. A completed NOT form, in accordance with the enclosed instructions, if final stabilization has been achieved on all portions of the site. The General Storm Water Permit defines final stabilization as "all soil disturbing activities at the site are complete and a uniform perennial vegetative cover (e.g., evenly distributed, without large bare areas) with a density of at least 70 percent cover for the area has been established on all unpaved areas and areas not covered by permanent structures or equivalent stabilization measures (such as the use of landscape mulches, rip-rap, gabions or geotextiles) have been employed. In addition, all temporary erosion and sediment control practices are removed and disposed of and all trapped sediment is permanently stabilized to prevent further erosion." For your convenience, the NOT form can be obtained from the following website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>; or
2. Submit written correspondence that states construction activities have not been completed on the site and the General Storm Water Permit will remain effective.

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via email at [chris.moody@epa.ohio.gov](mailto:chris.moody@epa.ohio.gov).

Sincerely,



Chris Moody  
Environmental Specialist II  
Division of Surface Water

CM/mt