



**Environmental
Protection Agency**

Tom Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korman, Director

July 14, 2010

RE: MEDINA COUNTY
SILVER CREEK BASIN
CITY OF WADSWORTH
WADSWORTH HIGH SCHOOL
AND COMMUNITY CAMPUS

Mr. Joe Magnacca
360 College Street
Wadsworth, OH 44281

Dear Mr. Magnacca:

On July 13, 2010, Ohio EPA conducted an inspection of the Wadsworth High School and Community Campus project, located at 625 Broad Street, City of Wadsworth, Medina County (site). Ohio EPA records indicate that the site is covered by the General National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04539*AG. I was accompanied by Don Husted of Turner Construction Company. The inspection documented the following:

- Inlet protection has been installed on the site's storm sewer inlets. A dandy bag near the construction entrance was observed to be damaged (Figure 1). Replace the dandy bag immediately. Maintain inlet protection in accordance with the site's storm water pollution prevention plan (SWP3).
- Sediment basin #1 was observed to be installed and functioning correctly.
- Currently, construction has been limited to the east end of the site. As earth disturbing activities commence throughout the remainder of the site, ensure that all erosion and sediment controls are installed per the site's SWP3.

Any above deficiencies must be addressed within 14 days of receiving this letter. Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,

Sean Green
Assistant to the District Engineer
Division of Surface Water

SG/mt

cc: Don Husted, Turner Construction Company




Figure 1. A dandy bag near the construction entrance has been damaged.