



**Environmental  
Protection Agency**

Gov. John Kasich, Governor  
Lt. Gov. Richard Cordusio, Lt. Governor  
Chris Korolowski, Director

June 2, 2010

RE: PORTAGE COUNTY  
CUYAHOGA RIVER BASIN  
CITY OF AURORA  
AURORA HIGH & MIDDLE SCHOOLS

Mr. William Volosin  
Aurora City Schools  
102 East Garfield Road  
Aurora, Ohio 44202

Dear Mr. Volosin:

On May 27, 2010 this office performed a compliance inspection of storm water best management practices (BMPs) at the above referenced site. Our records indicate that this site is covered by Ohio EPA General Storm Water Permit for Construction Activities # 3GC04302\*AG.

The inspection revealed that construction of the buildings and parking areas appeared to be at or near completion. Several areas of bare soils were observed that require stabilization. These areas should be seeded and mulched within 7 days of final grading. Other areas were noted to have been recently seeded and mulched for stabilization. Additional seeding and mulching may be needed to reach 70% coverage.

You are eligible to terminate the NPDES Permit once all of the following criteria are met:

- 1) All temporary erosion and sediment controls are removed and disposed.
- 2) All trapped sediments have been permanently stabilized to prevent further erosion.
- 3) All soil disturbing activities on this site have been completed.
- 4) A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing the enclosed Notice of Termination (NOT).

Should you have any questions, please contact me at (330) 963-1117.

Sincerely,

Kelvin F. Rogers  
Environmental Specialist  
Division of Surface Water

KFR/mt

enclosure

File: stormwater/construction

**Northeast District Office**  
2110 East Aurora Road  
Twinsburg, OH 44087-1924

330 | 963 1200  
330 | 487 0769 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)