



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 27, 2009

RE: PORTAGE COUNTY
CUYAHOGA RIVER BASIN
CITY OF KENT
AREA WIDE PROTECTION BUILDING

Mr. Bill Fink
D. F. Realty Associates, LLC
2641 S. Arlington Road
Akron, Ohio 44319

Dear Mr. Fink:

On May 8, 2009 this office performed a compliance inspection of storm water best management practices (BMPs) at the above referenced site. Our records indicate that this site is covered by Ohio EPA General Storm Water General Permit for Construction Activities # 3GC03540*AG.

The inspection revealed that building construction at this site is complete. Parking areas have been installed and perimeter areas were stabilized with grass/vegetation.

As such, you are eligible to terminate the NPDES Permit once all of the following criteria are met:

- 1) All temporary erosion and sediment controls are removed and disposed.
- 2) All trapped sediments have been permanently stabilized to prevent further erosion.
- 3) All soil disturbing activities on this site have been completed.
- 4) A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing the enclosed Notice of Termination (NOT).

Should you have any questions, please contact me at (330) 963-1117.

Sincerely,

Kelvin F. Rogers
Environmental Specialist
Division of Surface Water

KFR/mt

enclosure

File: stormwater/construction