



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Auglaize County
Blue Heron Bay Subdivision
Construction
Storm Water

October 28, 2009

CERTIFIED MAIL

Mr. Steve Klosterman
Klosterman Development Company
4696 U.S. Route 127
Celina, Ohio 45822

Dear Mr. Klosterman:

On September 24, 2009, I was conducting inspections of construction sites in Auglaize County in order to evaluate construction sites for compliance with the National Pollutant Discharge Elimination System (NPDES) Permit for storm water associated with construction activity. Inspections are conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

Klosterman Development Company holds a construction general permit or (CGP), Facility ID no. 2GC02368*AG for the site on the northeast corner of the Schneider Road and Koehn Road intersection. On this day I observed grubbing and clearing of the site. There were no sediment or erosion controls in place nor was there a construction entrance observed. *This is a violation of the CGP Part III.G.2.*

Please be aware that this construction site will be required to install post construction controls to address stormwater runoff quality and quantity.


Please submit to this office, within 10 days from the date of this letter, your SWP3 for this site and a written notification of the actions you propose to correct the above violations. Your written notification shall include the dates, either actual or proposed, for the completion of the actions. Your SWP3 shall fulfill all of the requirements of Part III, C of your permit.

Be advised that to ignore the conditions of the CGP and to fail to correct the violations of that permit will be cause for enforcement action against you.

Mr. Steve Klosterman
October 28, 2009
Page 2

If you should have any questions, please contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us.

Sincerely,



Patricia A. Tebbe, P.E.
Division of Surface Water

/llr

pc: DSW-NWDO:File
Auglaize County Engineer
Auglaize County SWCD
NWDO Follow-up File
Certified Receipt Number 7007 2560 0000 4479 2735