



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

RE: Auglaize County
Storm Water
Construction Activity
Permit No. 2GC01473*AG

November 9, 2010

Mr. Gary Binkley
Binkley Real Estate Inc.
121 West Auglaize St.
Wapakoneta, OH 45895

Dear Mr. Binkley:

On August 28, 2003, Binkley Real Estate Inc. received coverage under the Ohio EPA General Permit for Storm Water Associated with Construction Activity (CGP) for the South Ridge Subdivision in Wapakoneta. This CGP is still active and you are names as the contact.

On November 3, 2010, I performed an inspection of this site, located west of Ashland Avenue and Blackhoff St., Wapakoneta. The purpose of this visit was to evaluate compliance of the site with the CGP. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The development is completed and has achieved final stabilization

It was not apparent what structures were installed for the post-construction requirement which is found in Part III.G.2.e of the CGP. Please submit detail plans of the post-construction Best Management Practice that was installed for this development to me no later than 10 days from the date of this letter.

If you have any questions, please contact me at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/lb

pc: ~~INWDO=DSW-file~~