



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 24, 2011

RE: HARTVILLE HARDWARE HOME CENTER
3GC04993*AG
STARK COUNTY
LAKE TOWNSHIP

Mr. Ellis Erb
HRM Enterprises Inc.
1015 Edison Street
Hartville, Ohio 44632

Dear Mr. Erb:

On June 15, 2011 this writer met with Tom Erb at the above referenced construction site. The amended Stormwater Pollution Prevention Plan (SWPPP) calls for the construction of a sedimentation basin prior to discharging storm water from your site to the wetland. Reportedly, the construction of this basin and associated piping was to begin on June 20, 2011. On June 21, 2011 the construction has not yet begun. Please be advised that discharging to the wetland directly is considered an ongoing violation of your stormwater permit. The basin needs to be installed as soon as possible. If the basin is not installed by July 15, 2011, we will recommend that Stark Soil and Water Conservation District pursue an enforcement action.

If you should have any questions, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/mt

cc: Mike Kendall P.E., GBC Design, Inc.
Julie Barbari, Stark Soil & Water Conservation
Jean Siedel, U.S. Army Corps of Engineers, Huntington District
Lake Township Trustees