



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 19, 2011

RE: STARK COUNTY  
CITY OF CANTON  
BARBCO INC  
CONSTRUCTION STORM WATER

Mr. Jim Barbera  
Barbco Inc  
315 Pekin Drive SE  
East Canton, OH 44730

Dear Mr. Barbera:

On July 12, 2011, I, along with Julie Berbari of the Stark Soil & Water Conservation District (SWCD), performed an inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC04525\*AG. Our records indicate that Barbco Inc. was granted coverage under the NPDES permit on June 25, 2009.

During my inspection, I documented the following deficiencies:

1. Several gullies have formed along the slopes. Please repair and stabilize these gullies to prevent further erosion. In addition, please ensure that the runoff that enters the swale at the bottom of the slope is carried to the sediment basin, where it can then be treated and discharged.
2. The disturbed area in the rear of the site lacks stabilization. If no construction activities will occur in this area within the next 21 days, or if this area has reached final grade, you must seed and mulch all bare soil within seven days of the last earth disturbance.

Please provide me with a letter of response indicating the actions you will take to address the deficiencies noted above. Your response, along with any amendments to the Storm Water Pollution Prevention Plan (SWP3), must be submitted to the Ohio EPA **no later than August 1, 2011**. If corrective actions are not completed by this date, please include a schedule that outlines when action will be taken. It is Ohio EPA's expectation that all of these deficiencies will be addressed within 10 days of receipt of this letter.


Finally, please fax a copy of your most recent storm water inspection report to my attention at (330) 487-0769 or via e-mail at [michelle.hummel@epa.state.oh.us](mailto:michelle.hummel@epa.state.oh.us). The

Mr. Jim Barbera  
Barbco Inc  
July 19, 2011  
Page 2

NPDES permit requires you to inspect all storm water best management practices once every 7 days and within 24 hours of a 0.5-inch or greater rainfall. The results of these inspections must be documented as indicated in Part III.G.2.i of the NPDES permit.

If you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,



Michelle Hummel  
Assistant to the District Engineer  
Division of Surface Water

MH/mt

cc: Dan Moeglin, Engineer, City of Canton  
Warren Price, MS4 Program Manager, City of Canton  
William Healy, Mayor, City of Canton  
Julie Barbari, Stark SWCD

ec: Phil Rhodes, DSW, NEDO