

**Environmental
Protection Agency**

**Governor
Lt. Governor
Director**

August 4, 2011

RE: STARK COUNTY
CITY OF LOUISVILLE
LOUISVILLE HIGH SCHOOL ADDITIONS
& RENOVATIONS
CONSTRUCTION STORM WATER

David Redd
Louisville City School District
504 E Main Street
Louisville, OH 44641

Dear Mr. Redd:

On August 2, 2011, I, along with Julie Berbari of the Stark Soil & Water Conservation District (SWCD), performed a follow-up inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC04824*AG. Our records indicate that the Louisville City School District was granted coverage under the NPDES permit on March 4, 2010.

During my inspection, I documented the following deficiencies:

1. Sediment has collected on the Dandy Bags that are covering the storm drains. Please clean and reinstall these Dandy Bags.
2. I was unable to locate a designated concrete washout on the site. According to the NPDES permit, water that comes in contact with concrete is considered waste water and cannot leave the site. As a result, you must designate contained areas for concrete washout, and these locations must be outlined in your Storm Water Pollution Prevention Plan (SWP3). Please install an appropriate washout before conducting any further work with concrete.


Please provide me with a letter of response indicating the actions you will take to address the deficiencies noted above. Your response, along with any amendments to the SWP3, must be submitted to the Ohio EPA **no later than August 18, 2011**. If corrective actions are not completed by this date, please include a schedule that outlines when action will be taken. It is Ohio EPA's expectation that all of these deficiencies will be addressed within 10 days of receipt of this letter.

Finally, please fax a copy of your most recent storm water inspection report to my attention at (330) 487-0769 or via e-mail at michelle.hummel@epa.state.oh.us. The NPDES permit requires you to inspect all storm water best management practices once every 7 days and within 24 hours of a 0.5-inch or greater rainfall. The results of these inspections must be documented as indicated in Part III.G.2.i of the NPDES permit.

DAVID REDD
AUGUST 4, 2011
PAGE 2

If you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128. You may also contact Phil Rhodes of the Ohio EPA at (330) 963-1136.

Sincerely,

A handwritten signature in cursive script, appearing to read "Michelle Hummel".

Michelle Hummel
Assistant to the District Engineer
Division of Surface Water

MH:bo

pc: E. Thomas Ault, MS4 Program Manager, City of Louisville
Patricia Fallot, Mayor, City of Louisville
Julie Berbari, Stark SWCD

ec: Phil Rhodes, DSW, NEDO