

**Environmental
Protection Agency**

**Governor
Lt. Governor
Director**

August 4, 2011

RE: STARK COUNTY
TUSCARAWAS TOWNSHIP
STATE ROUTE 93 TURNING LANES
CONSTRUCTION STORM WATER

Al Osler
Tuslaw Local School District
1835 Manchester Avenue NW
Massillon, OH 44647

and

Curt Walker
Superior Paving and Materials Inc
5945 Whipple Avenue NW
North Canton, OH 44720

Dear Mr. Osler and Mr. Walker:

On August 2, 2011, I, along with Julie Berbari of the Stark Soil & Water Conservation District (SWCD), performed a follow-up inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05471*AG. Our records indicate that Tuslaw Local School District was granted coverage under the NPDES permit on May 25, 2011. Our records further indicate that Superior Paving and Materials Inc. submitted a Co-Permittee Notice of Intent on May 25, 2011.

It appears that construction on this project is complete and the site has been stabilized. When you determine that the entire site has achieved a vegetative growth density of 70% or greater on all unpaved surfaces, you should remove all temporary sediment controls, including inlet protection, and then submit a Notice of Termination (NOT) to the Ohio EPA to terminate NPDES permit coverage. The form and instructions are available on our website at www.epa.ohio.gov/dsw/storm/stormform.aspx.

Finally, please fax a copy of your most recent storm water inspection report to my attention at (330) 487-0769 or via e-mail at michelle.hummel@epa.state.oh.us. The NPDES permit requires you to inspect all storm water best management practices once every 7 days and within 24 hours of a 0.5-inch or greater rainfall. The results of these inspections must be documented as indicated in Part III.G.2.i of the NPDES permit.

AL OSLER
CURT WALKER
AUGUST 4, 2011
PAGE 2

If you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128. You may also contact Phil Rhodes of the Ohio EPA at (330) 963-1136.

Sincerely,

A handwritten signature in black ink, appearing to read "Michelle Hummel". The signature is fluid and cursive, with a small flourish at the end.

Michelle Hummel
Assistant to the District Engineer
Division of Surface Water

MH:bo

pc: Keith Bennett, Engineer, Stark County
Trustees, Tuscarawas Township
Julie Berbari, Stark SWCD

ec: Phil Rhodes, DSW, NEDO