



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 9, 2009

RE: **SUMMIT COUNTY  
CUYAHOGA RIVER BASIN  
CITY OF AKRON  
WATERLOO ROAD TOWPATH TRAIL**

Ms. Christine Jonke  
City of Akron  
166 South High Street, Room 701  
Akron, Ohio 44308

Dear Ms. Jonke:

On November 3, 2009, this office performed a compliance inspection of storm water best management practices (BMPs) at the above referenced site. Our records indicate that this site is covered by Ohio EPA General Storm Water General Permit for Construction Activities # 3GC03903\*AG.

The inspection revealed that the parking area and trail construction at this site is complete. All berm areas appeared to be well stabilized with grass/vegetation.

As such, you are eligible to terminate the NPDES Permit once all of the following criteria are met:

- 1) All temporary erosion and sediment controls are removed and disposed.
- 2) All trapped sediments have been permanently stabilized to prevent further erosion.
- 3) All soil disturbing activities on this site have been completed.
- 4) A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing the enclosed Notice of Termination (NOT).

Should you have any questions, please contact me at 330-963-1117.

Sincerely,

Kelvin F. Rogers  
Environmental Specialist  
Division of Surface Water

KFR:bo

enclosure

File: stormwater/construction