

**Environmental  
Protection Agency**

\_\_\_\_\_, Governor  
\_\_\_\_\_, Lt. Governor  
\_\_\_\_\_, Director

May 18, 2010

RE: SUMMIT COUNTY  
CUYAHOGA RIVER BASIN  
CITY OF CUYAHOGA FALLS  
FRONTLINE INTERNATIONAL INC.

Mr. John Pallazzo  
Frontline International Inc.  
95 16<sup>th</sup> Street NW  
Barberton, Ohio 44203

Dear Mr. Pallazzo:

On May 17, 2010 this office performed a compliance inspection of storm water best management practices (BMPs) at the above referenced site. Our records indicate that this site is covered by Ohio EPA General Storm Water General Permit for Construction Activities # 3GC04496\*AG.

The inspection revealed that the building and parking/drive area construction at this site is complete. All perimeter areas have been stabilized with grass and landscaping.

As such, you are eligible to terminate the NPDES Permit once all of the following criteria are met:

- 1) All temporary erosion and sediment controls are removed and disposed.
- 2) All trapped sediments have been permanently stabilized to prevent further erosion.
- 3) All soil disturbing activities on this site have been completed.
- 4) A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing the enclosed Notice of Termination (NOT).

Should you have any questions, please contact me at (330) 963-1117.

Sincerely,



Kelvin F. Rogers  
Environmental Specialist  
Division of Surface Water

KFR/mt

Enclosure

File: stormwater/construction