



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 15, 2010

**RE: SUMMIT COUNTY
CUYAHOGA RIVER BASIN
CITY OF STOW
CLUNK OFFICE BUILDING**

Mr. Tom Finley
Pride One Omni, LLC
29225 Chagrin Boulevard, Suite 285
Pepper Pike, Ohio 44122

Dear Mr. Finley:

On March 12, 2010 this office performed a compliance inspection of storm water best management practices (BMPs) at the above referenced site. Our records indicate that this site is covered by Ohio EPA General Storm Water General Permit for Construction Activities # 3GC03826*AG.

The inspection revealed that building and parking area construction at this site is complete. Landscaping and stabilization of perimeter areas have been completed.

As such, you are eligible to terminate the NPDES Permit once all of the following criteria are met:

- 1) All temporary erosion and sediment controls are removed and disposed.
- 2) All trapped sediments have been permanently stabilized to prevent further erosion.
- 3) All soil disturbing activities on this site have been completed.
- 4) A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing the enclosed Notice of Termination (NOT).

Should you have any questions, please contact me at (330) 963-1117.

Sincerely,

Kelvin F. Rogers
Environmental Specialist
Division of Surface Water

Enclosure

KFR/mt

File: stormwater/construction