



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 25, 2009

RE: SUMMIT COUNTY
CUYAHOGA RIVER BASIN
CITY OF STOW
MEDICAL OFFICE COMPONENT
AKRON GENERAL

Mr. Joseph Plavecski
Akron General Medical Center
400 Wabash Avenue
Akron, Ohio 44307

Dear Mr. Plavecski:

On August 19, 2009 this office performed a compliance inspection of storm water best management practices (BMPs) at the above referenced site. Our records indicate that this site is covered by Ohio EPA General Storm Water General Permit for Construction Activities # 3GC03904*AG.

The inspection revealed that building construction at this site is complete. Landscaping has been installed and areas of bare soils at final grade were being stabilized with seeding/mulching. The site sediment ponds appeared to be well stabilized with vegetation.

As such, you are eligible to terminate the NPDES Permit once all of the following criteria are met:

- 1) All temporary erosion and sediment controls are removed and disposed.
- 2) All trapped sediments have been permanently stabilized to prevent further erosion.
- 3) All soil disturbing activities on this site have been completed.
- 4) A uniform, perennial vegetative cover (or other permanent stabilization technique) has been established to a 70% growth density on all disturbed soils.

This permit may be terminated by filing the enclosed Notice of Termination (NOT).

Should you have any questions, please contact me at (330) 963-1117.

Sincerely,

Kelvin F. Rogers
Environmental Specialist
Division of Surface Water

KFR/mt

Enclosure

File: stormwater/construction