



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 11, 2011

RE: WAYNE COUNTY  
CANAAN TOWNSHIP  
CHIPPEWA SUBDIST OF MWCD  
FLOOD CONTROL STRUCTURE V-D  
CONSTRUCTION STORM WATER

Ms. Deborah Russell  
Muskingum Watershed Conservancy District  
1319 Third Street NW  
P.O. Box 349  
New Philadelphia, OH 44663

Mr. Mark Haynes  
Mark Haynes Construction Inc.  
3130 State Route 18 E  
Norwalk, OH 44857

Dear Ms. Russell and Mr. Haynes:

On June 28, 2011, I, along with Robert Kastner of the Wayne Soil & Water Conservation District (SWCD), performed an inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05109\*AG. Our records indicate that the Muskingum Watershed Conservancy District was granted coverage under the NPDES permit on September 20, 2010. Our records further indicate that Mark Haynes Construction Inc. submitted a Co-Permittee Notice of Intent on October 15, 2010.

During my inspection, I documented the following deficiencies:

1. Some of the sediment that was placed on the farm fields along Irvin and Steiner Roads has not been stabilized. As a result, erosion gullies have formed, and sediment is flowing into the ditch along Irvin Road and the drainage swale that crosses Steiner Road. If this soil will not be worked within 21 days, you must temporarily stabilize these areas within seven days of the last earth disturbance. Otherwise, you must install silt fence along the boundaries of all disturbed soil.
2. Sediment has washed onto Steiner Road. Please clean the streets and ensure that vegetation establishes itself on the neighboring fields to prevent additional sediment from reaching the roadway.

Ms. Deborah Russell and Mr. Mark Haynes  
Chippewa Subdist. of MWCD Flood Control Structure V-D  
July 11, 2011  
Page 2

Please provide me with a letter of response indicating the actions you will take to address the deficiencies noted above. Your response, along with any amendments to the SWP3, must be submitted to the Ohio EPA **no later than July 22, 2011**. If corrective actions are not completed by this date, please include a schedule that outlines when action will be taken. It is Ohio EPA's expectation that all of these deficiencies will be addressed within 10 days of receipt of this letter.

Finally, please fax a copy of your most recent storm water inspection report to my attention at (330) 487-0769 or via e-mail at [michelle.hummel@epa.state.oh.us](mailto:michelle.hummel@epa.state.oh.us). The NPDES permit requires you to inspect all storm water best management practices once every 7 days and within 24 hours of a 0.5-inch or greater rainfall. The results of these inspections must be documented as indicated in Part III.G.2.i of the NPDES permit.

If you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1128.

Sincerely,



Michelle Hummel  
Assistant to the District Engineer  
Division of Surface Water

MH/mt

cc: Roger Terrill, Engineer, Wayne County  
Trustees, Canaan Township  
Robert Kastner, Wayne SWCD

ec: Dan Bogoevski, Ohio EPA, NEDO, DSW