



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 19, 2009

RE: WAYNE COUNTY
MUSKINGUM RIVER BASIN
CITY OF ORRVILLE
UNIVERSITY OF AKRON
WAYNE COLLEGE

Mr. Michael Deiwert
The University of Akron Wayne College
1901 Smucker Road
Orrville, Ohio 44667

Dear Mr. Deiwert:

On October 6, 2009 this office performed a compliance inspection of storm water best management practices (BMPs) at the above referenced site. Our records indicate that this site is covered by Ohio EPA General Storm Water Permit for Construction Activities # 3GC03795*AG.

The inspection revealed that the new parking area has been installed and striped. However, the following items remain to be addressed:

- Several areas of bare soils were observed, including berm areas and a large section north of the new parking area. These areas appeared to be at final grade but were not being stabilized at the time of the inspection. **All bare soils should be stabilized with grass seeding and mulch immediately if they are to remain idle longer than 21 days.** A dormant seed mix may be utilized at this time of year if needed.
- Silt fencing along the perimeter of the site appeared to be in need of repair and maintenance. **All silt fencing should be inspected immediately and repaired or replaced as needed.** Collected sediment behind silt fence or built up in the sediment pond/trap should be removed and placed upland for disposal. The silt fencing should be removed after the area is completely stabilized with vegetation.

Please provide this office with a letter of response, indicating the corrective action you will take to address these deficiencies, within 7 days of receipt of this letter. All corrective actions should be completed by November 9, 2009.

Should you have any questions, please contact me at (330) 963-1117.

Sincerely,

Kelvin F. Rogers
Environmental Specialist
Division of Surface Water

KFR/mt

File: stormwater/construction